



## DI-60XE & DI-60XT Programmable Meter Controllers Tiger 320 Series PMCs 6 Digit 0.56" LCD in a 1/8 DIN Case

A powerful, intelligent, 6-digit Programmable Meter Controller (PMC) with modular outputs, input signal conditioning and advanced software features for monitoring, measurement, control and communication applications.

### General Features

- The Tiger 320 Operating System supports an easy to use PC based Configuration Utility Program, which can be downloaded FREE from the web, and programming from front panel buttons.
- The T Version supports custom macro programs that can be easily produced with the Tiger 320 Macro Development System (available FREE on the web). The Development System enables programs to be written in BASIC, which can utilize any combination of the hundreds of functions and thousands of registers embedded in the Tiger 320 Operating System.
- 7-segment, 0.56" high LCD with full support for seven segment alphanumeric text.
- Brightness (Contrast) control of LCD display from front panel buttons.
- Modular construction with more than 120 interchangeable input signal conditioners and more than 25 interchangeable I/O modules.
- Up to 4 input channels with cross channel math for multi-channel processing.
- For applications where sensor excitation is required, modules are provided with 5V, 10V or 24 V DC voltage outputs.
- On demand tare, calibration and compensation can be initiated by the front panel program button.
- Autozero maintenance for super stable zero reading is provided for use in weighing applications.
- Programmable input averaging and smart digital filtering for quick response to input signal changes.
- Display text editing. Customize display text for OEM applications.
- Scrolling display text messaging on T meters with macros.
- Auto-sensing high voltage or optional low voltage AC / DC power supply.
- Serial output options include RS-232, RS-485, ModBus,

Ethernet, DeviceNet or direct meter-to-meter communications.

- Single or dual 16-bit Isolated Analog Outputs. Programmable 0~4 to 20mA or 0 to 10V for retransmission, 4-20mA loops to drive valve actuators, remote controllers & displays, multi-loop feedback and PID output. Scalable from 1 count to full scale.
- Dual independent totalizers to integrate input signals.
- 6 super smart, independently programmable setpoints with 8 selectable functions, including latching, deviation, hysteresis, register resetting, tracking and dual PID. Plus 7 programmable timer modes on all 6 setpoints.
- Setpoint tracking, setpoint latching and manual relay reset.
- Setpoints activated from any input, any register in the meter or from any digital input.
- Plug-in I/O modules include electromechanical or solid state relays, logic outputs or open collector outputs. 6 inputs & 16 outputs of opto-isolated I/O can be connected to an external DIN Rail terminal block module.
- Internal program safety lockout switch to prevent tampering.
- Peak & valley (max & min) with front panel recall and reset.
- Real time clock with 15 year Lithium battery backup.
- Data logging within the meter (up to 4000 samples with date/time stamp).
- Optional NEMA-4 front cover.

### Input Module Compatibility

**TIGER FAMILY:** More than 120 different Plug-in I-Series Input Signal Conditioners are approved for the Tiger Family of meters.

See *I-Series Input Signal Conditioning Modules Guide (Z87)* for an up-to-date list.





### Table of Contents

General Features . . . . .	1	Controls & Indicators . . . . .	14-15	Functional Diagram . . . . .	45
Specifications . . . . .	2	Front Panel Configuration & Setup . . . . .	16	Connector Pinouts . . . . .	45
Tiger 320 Series Literature Overview . . . . .	3	Front Panel Programming Codes . . . . .	17-18	Carrier Board Output Pins . . . . .	46
Tiger 320 Series System Overview . . . . .	4-5	Initial Setup Procedures . . . . .	19-20	Relay and Logic I/O Modules . . . . .	46
Planning to Use the Tiger 320 . . . . .	6-8	Display Brightness . . . . .	20	Component Layout & Ext. Devices . . . . .	47-48
Block Diagram of Tiger 320 Structure . . . . .	9	Calibration Modes . . . . .	21-24	I-Series Input Modules . . . . .	49-55
Configuration Utility Program . . . . .	10	Programming Procedures . . . . .	25-37	Ordering Information . . . . .	56-58
Custom Macro Program . . . . .	11	Setpoint Programming Mode . . . . .	38-43	Custom Faceplates . . . . .	59
Index . . . . .	12-13	Registers . . . . .	44	Case Dimensions . . . . .	60

# Specifications

## Display

- Digital Display:** 7-segment, 0.56" (14.2 mm) Reflective LCDs.
- Digital Display Range:** -199999 to 999999
- Update Rate:** 3 to 10 times per second
- Display Dimming:** 8 brightness (contrast) levels. Front Panel selectable
- Scrolling Display Text Messaging:** Full alphanumeric, 7-segment text characters supported on T Version with macros.
- Polarity:** Assumed positive. Displays - negative
- Decimal Point:** Front panel, user selectable to five positions.
- Overrange Indication:** 
- Underrange Indication:** 
- Front Panel Controls:** PROGRAM, UP and DOWN.

## Operating System (Tiger 320)

- Processor:** 32 bit with floating point maths (18.4 MHz).
- Flash Memory:** 64k, 4k for use by custom macros.
- RAM:** 1.25k and FeRAM 4k.
- EEPROM:** E Version 4k standard, T Version 32k standard. Memory upgrades available to 32k for LIN Tables and 1MB for Data Logging and custom macros.
- Registers:** 6144 registers comprised of 8, 16 or 32 bit signed, unsigned or floating point registers, implemented in a combination of RAM, FeRAM, Flash and EEPROM.
- Internal communication BUS:** 32 bit I<sup>2</sup>C BUS
- Real Time Clock (option):** Year:Month:Date:Hour:Minute:Second with 15 yr Lithium battery backup.
- Configuration:** Supports Front Panel Programming Codes and a PC-based Configuration Utility Program, which may be downloaded free from the web. T Version also supports custom macros.

## Development System for Custom Macros

The Tiger 320 Macro Development System, which may be downloaded free from the web, can be used to create powerful macro software that allows Tiger 320 T Versions to be easily customized to suit any proprietary OEM application (see page 11).

## Installed Application Software Includes

- Counter Functions:** Two built-in counters. UP counters, DOWN counters, UP/DOWN counters and high speed quadrature counters.
- Data Logging:** Logging with a date/time stamp, initiated at timed intervals, by activation of a setpoint, or manually. Data stored in internal 1MB EEPROM or in a removable 4 to 128M Flash Card Memory Module. Endless loop recording is supported.
- Input Compensation:** Provides compensation to the primary input channel (CH1) via channels 2, 3 or 4.
- Linearization:** 4 selectable 32 point or one 125 point flexible linearization tables are provided.
- Logic I/O:** 28 Macro programmable I/O ports supported.
- Manual Loader:** Front panel adjustable, 4 to 20mA or 0 to 10V isolated analog output.
- Math Functions:** Cross channel math functions to calculate the sum, difference, ratio or the product of two inputs.
- On Demand Functions:** Tare, compensation and calibration.
- Peak and Valley:** The meter can retain peak and valley (min/max) information and recall this on the front panel.
- Remote Setpoint Input:** Remote setpoint input via channel 2.
- Serial Output Protocols:** Selectable communication modes include ASCII, Modbus (RTU), Master Mode (for meter to meter communication) and an Epson compatible printer driver. DeviceNet and Ethernet optional output carrier boards are also supported.
- Setpoint Functions:** Six super smart setpoints with fully configurable hysteresis, on and off delays, one shot, pulse and repeat timers, latching, dual PID, setpoint tracking, resetting of registers, initiating of logging and printing.
- Signal Conditioning Functions:** Averaging, smart filter, rounding, square root, auto zero maintenance.
- Timer:** Timer functions supported in either time-up, time-down, or real-time clock modes.
- Totalizer:** Two totalizers for running total and batch totals of a process signal that can be accumulated over time.

## Inputs

- Inputs Available:** More than 120 single, dual, triple and quad input signal conditioners available covering all types of analog, digital and mixed input signals (see page 49).
- Accuracy:** Tiger 320 PMCs enable the user to establish any degree of system accuracy required. Built-in compensation and linearization functions enable system accuracies of the order of  $\pm 0.0001\%$  of reading for analog inputs. Stop -Start time resolution from  $\pm 1\text{sec}$  to  $\pm 0.7\text{nsec}$ . Digital input and pulse counts  $\pm 1$  count.
- A/D Convertors:** A Dual Slope, bipolar 17 bit A/D is provided as standard on the main board. SMART modules can have 24 bit or 16 bit Delta-Sigma A/D convertors that utilize the internal I<sup>2</sup>C BUS.
- Temperature Coefficient:** Typically 30ppm/<sup>o</sup>C. Compensation can be utilized to achieve system temperature coefficients of 1ppm.
- Warm Up Time:** Up to 10 minutes, depending on input module.
- Conversion Rate:** Typically 10 samples per second. However, SMART input modules are available that can convert at 60, 240, 480 or 960 samples per second.
- Control Output Rate:** Can be selected for 100msec or 10msec. Some SMART modules have SSR outputs that react within 1.2msec.
- Excitation Voltage:** Depends on input module selected. Typically, 5V, 10V or 24VDC is provided.

## Outputs (See pages 46-47 for pinouts and details of modular construction)

- Three Optional Plug-in Carrier Boards:** Provide four different serial outputs or no serial output, support single or dual analog outputs, and accept any one of seven different plug-in I/O modules.
- 1. Standard Carrier Board:** Is available without a serial output, or with either an isolated RS-232 or an isolated RS-485 (RJ-6 socket).
  - 2. DeviceNet Carrier Board:** 5 pin 3.5mm screw terminal.
  - 3. Ethernet Carrier Board:** 10/100Base-T Ethernet (RJ-45 socket).
- Two Isolated Analog Output Options:** Mounted on any carrier board.
- 1. Single Analog Output:** Fully scalable from 4 to 20mA or 0 to 20mA (or reverse) and selectable for 0 to 10VDC (or reverse).
  - 2. Dual Analog Output:** Fully scalable from 0 to 10VDC (or reverse).

**Analog Output Specifications:** Accuracy: 0.02% FS. Resolution: 16-bit Delta-Sigma D/A provides 0.4 $\mu$ A on current scaling, 250 $\mu$ V on voltage scaling. Compliance: 500 $\Omega$  maximum for current output. 500 $\Omega$  minimum for voltage output. Update Rate: Typical 7 per second. Step Response: Typical 6msec to a display change. Scalable: From 1 count to full scale.

## Seven I/O Modules: Plug into any carrier board from rear.

- 1. Four Relay Module:** Available in six combinations from one relay up to a total of two 10A Form C Relays\* and two 5A Form A Relays\*\*.
- 2. Four Relay Module:** Available with one to four 5A Form A Relays\*\*.
- 3. Six Relay Module:** Available with five or six 5A Form A Relays\*\*.  
\*Form C Relay Specifications: 10A 240VAC-1/2 HP, 8A 24VDC. Isolation 3000V. UL and CSA listed.  
\*\*Form A Relay Specifications: 5A 240VAC, 4A 24VDC. Isolation 3000V. UL and CSA listed.
- 4. Four Solid State Relay (SSR) Module:** Available with one to four independent (210mA DC only) or (140mA AC/DC) SSRs (400V max).
- 5. Six Output 5VDC / TTL or Open Collector:** Available with 0 to 5V or 0 to V+ (40VDC max).
- 6. Opto Isolated I/O Module:** Available in either 6 Outputs & 6 Inputs, or 16 Outputs and 6 Inputs. For connection to an external breakout box.
- 7. Flash Card Memory Module:** Available with 8 or 16 MB memory.

## Power Supplies

- Auto sensing AC/DC (DC to 400Hz) hi volts std, low volts optional.
- PS1 (standard):** 85-265VAC / 95-370VDC @ 4W max 5W.
- PS2 (optional):** 14-48VAC / 10-72 VDC @ 4W max 5W.

## Environmental (See Rear page for IP-65 & NEMA-4 options)

- Operating Temperature:** 0 to 50 <sup>o</sup>C (32 <sup>o</sup>F to 122 <sup>o</sup>F).
- Storage Temperature:** -20 <sup>o</sup>C to 70 <sup>o</sup>C (-4 <sup>o</sup>F to 158 <sup>o</sup>F).
- Relative Humidity:** 95% (non-condensing) at 40 <sup>o</sup>C (104 <sup>o</sup>F).

## Mechanical (See Rear page for more details)

- Case Dimensions:** 1/8 DIN, 96x48mm (3.78" x 1.89")
- Case Material:** 94V-0 UL rated self-extinguishing polycarbonate.
- Weight:** 11.5 oz (0.79 lbs), 14 oz (0.96 lbs) when packed.

## Approvals

CE: As per EN-61000-3/4/6 and EN-61010-1.

# Tiger 320 Series Modular Literature Overview

►► The Tiger 320 Series, Modular Literature system, makes it easy to select detailed information about those specific functions required for your application and the Configuration of the Tiger 320 you intend using.

Copies of all Data Sheets / User Manuals and Supplements can be viewed page-by-page and/or downloaded from the document server on our website.

## Programming Code Sheet

Generic to all Tiger 320 Series models, the Programming Code Sheet is a quick reference document that allows you to quickly view the meter's manual programming codes.



Shipped with each product ordered, copies are also available on request, or can be viewed and downloaded from the document server on our website.

## Model Specific Data Sheet / User Manual




Specific to each 320 Series meter model, the data sheet / user manual describes the basic functions of the meter and how to configure the meter for these functions.

Shipped with each product ordered, copies are also available on request, or can be viewed and downloaded from the document server on our website.

The model specific data sheet / user manual contains:

- Technical Specifications
- Overview of Tiger 320 Series Software and Hardware
- Planning Guide
- Block Diagram of the Tiger 320 Software and Hardware
- Configuration Utility Program
- Custom Macro Programming
- Front and Rear Panel Controls
- Front Panel Button Manual Programming Codes Overview
- Programming Procedures
- Functional Diagram and Pinouts
- Hardware Layout and Available Input and Output Modules
- Meter Options, and Custom Faceplates
- Ordering Information

## Supplements to Data Sheet / User Manual are Generic to all Tiger 320 Models



Generic to all Tiger 320 Series models, each supplement provides in-depth technical and procedural information on all individual meter modules, functions, or applications.

Listed are the supplements which are currently available:

Specific supplements are shipped with each product ordered to suit our customer's application. Copies are also available on request, or can be viewed and downloaded from the document server on our website.

- Advanced Calibration and On DEMAND Mode
- Analog Output Modules
- BASIC to Tiger 320 MACRO-Language Program Development System, Compiler and Tutorial
- Configuration Utility Program (Runs on PC)
- Linearizing Functions
- Meter Registers (for Macro Programming)
- Serial Communications Output Modules
- Setpoints & Relays
- Totalizing & Batching Functions

## Other Tiger 320 Series Related Literature

### Tiger 320 Functional Overview



A Quick Overview of the Awesome Power of the Tiger 320 Series

### Tiger 320 Application Examples



Describes a Selection of Tiger 320 Applications

### I-Series Input Signal Conditioning Modules



Includes all Available Input and Output Modules for the Tiger, Leopard and Lynx Families of Meters

### Meters By the Case Size



Shows all Cases and Lists all Available Meters by Each Case Size and Type

# An Overview of the Awesome Power of the Tiger 320 Series

The Tiger 320 Series of 32-bit Programmable Meter Controllers incorporates, in one instrument, all the different functions required by today's automation and process control applications.

## 1 Tiger 320 32-Bit Operating System

A virtual toolbox of selectable and programmable application software functions are embedded in the Tiger 320 Operating System. They integrate seamlessly with a truly vast array of modular input and output hardware options.

**Embedded Application Software Includes:**

- Multi-channel Inputs In Many Combinations
- Full Floating-point Maths
- Cross Channel Math (A+B, A-B, AxB, A/B)
- Square Root, Inverse and Log of Input
- 4 x 32 Point Or 1 x 125 Point Linearization Table
- Smart Auto Zero with Programmable Capture Band, Rate of Change and Aperture Window for Weighing Applications
- Set Tare Reset Tare for Batching
- Smart Quick Response Averaging
- Smart Timer and Time Integration Functions
- Time and Event-based Sequencing
- Polynomial Calculations
- Remote Reset of Any Function
- Dual Totalizers
- Dual PID


## 2 Data Logging and Memory Options

Up to 1MB of non-volatile on-board memory can be installed for (Black Box) endless loop recording. Up to 4000 data records can be continuously stored to provide before and after analysis of any process fault condition.

- Data log from 4 channels.
- Data log from 2 channels with date & time stamp.
- Log / print from setpoint or timer.

A Plug-in I/O Module is available with removable Flash Card Memory for high-capacity or long-term data logging.

Flash Cards are available from 4 to 128 Meg.




## 3 Real-time Clock



Optional Real-time clock with date and time stamp.

15 year lithium battery.



## 4 Powerful Custom Macro Programming Capability

Texmate's BASIC to Tiger 320 Macro-language Compiler can quickly Convert your special metering, control and automation ideas into reality.

This powerful easy to use development system enables programs to be written in BASIC utilizing any combination of the hundreds of functions and thousands of registers embedded in the Tiger 320 Operating System. When your BASIC program is compiled into the Tiger 320 Macro-language it is error checked and optimized. There are also numerous off-the-shelf application specific programs available. Many only need the blanks to be filled in to use them and this does not require any knowledge of BASIC.




Scrolling annunciator messages can be programmed to appear with any setpoint activation, selected events or logic inputs.



## 5 Programmable Front Panel Controls

**Programmable Front Panel Controls**

The front panel buttons can be used to control or program any standard functions.




They can also be programmed to only access and display specifically designated functions, such as Tare, Auto-Cal or Print on Demand.

## 6 Configuration & Programming from a PC

**PC Programming**


Program the meter from a PC with Texmate's easy to use Tiger 320 Configuration Utility Program.



## 7 A Wide Selection of Display Formats & 8 Case Sizes to Suit any Application

Single or multiple LED or LCD displays  
Numeric, Alpha Numeric and Bargraph

144x72mm 9/32 DIN



96x48mm 1/8 DIN



48x96mm 1/8 DIN



36x144mm 9/64 DIN



648x144mm 4" LED Remote Display 5 or 6 digit Driven by RS485 from any Tiger 320




## 8 22 Opto-Isolated I/Os on Plug-in Module & 6 Onboard Programmable I/O Logic Ports

- 6 Inputs & 16 Outputs or 6 Inputs & 6 Outputs
- Fully Programmable




Connects to DIN Rail terminal block module with 3M IDC cable




Three logic level inputs are provided on the module input header and three rear input pins are provided that can be programmed to STOP/START/RESET almost any function including: set tare, reset tare, relays, totalizers, print output, data logging, peak, valley, or any register from an external contact closure.

## 9 6 Super Smart Setpoints - 8 Selectable Functions - 7 Programmable Timer Modes



Serial module  
Analog Output module  
Output Module Carrier Board




Single & Multiple Activation Timers

5 A  
10 A  
5 Amp and 10 Amp Relays or optional SSR Outputs can be energized above or below setpoints.

### 7 Multi Function Interval Timers on all 6 setpoints


- Normal .....Adjustable Delay On Make / Adjustable Delay On Break
- 1-Shot ON .....Adjustable Delay On Make / Adjustable Min ON-Time
- 1-Shot OFF .....Adjustable Delay On Break / Adjustable Min OFF-Time
- Pulse ON .....Adjustable Delay On Make / Adjustable Max ON-Time
- Pulse OFF .....Adjustable Delay On Break / Adjustable Max OFF-Time
- Repeat ON .....Adjustable ON-Time / Adjustable OFF-Time
- Repeat OFF .....Adjustable OFF-Time / Adjustable ON-Time




Dual PID

## 10 Scrolling Annunciator

Scrolling Annunciator up to 99 Characters long is available on all 6 setpoints for Alphanumeric Displays with Fill-in-the-blanks Macro.



Activation



Relay Latching




SETPOINT TRACKING

\*99 CHARACTER SCROLLING DISPLAY ON ALL SETPOINTS




## 12 16-bit Isolated Analog Outputs

Single



0 ~ 4-20mA or 0-10V

Dual




0-10V & 0-10V

Programmable 0~4 to 20 mA or 0 to 10 V for retransmission, 4-20 mA loops, drive valve actuators, remote controllers & displays, multi-loop feedback and PID output.

## 11 Serial Communications & Printer Output

RS-232



RS-485


Selectable Communication Modes include:

- ASCII
- Modbus
- Ethernet (TCP/IP)
- Devicenet (with optional carrier board installed)

Interface directly with PCs (using Window's terminal program), PLCs, or any Epson compatible serial printer.


Serial Printer Output

Smart printer driver makes simple serial printers look intelligent.




Meter to Meter Communication.

Direct meter to meter communication enables two meters to share data and resources.




## 13 Auto-sensing AC/DC Power Supply

- High Efficiency CE tested Auto Sensing AC/DC power supplies.
  - Standard 85-265 Volt AC / 95-370 Volt DC.
  - Low Voltage 9-32 Volt AC / 10-60 Volt DC.




## 14 Over 120 Different Input Signal Conditioning Modules

- Choose from over 120 different single, dual, triple and quad input signal conditioners.
- Mixed function and smart modules with their own A/Ds, co-processors, SSRs and I<sup>2</sup>C Bus outputs are available to suit almost any application.



AC-Amps True RMS 0-5Amp AC



A combination of modular hardware and software resources enable Tiger 320 Series Programmable Meter Controllers (PMCs) to be easily configured as a cost effective solution for the most simple or the most complex of applications.

A review of your Project's objectives, its physical layout, the proposed sensors and control outputs will enable you to select the optimum configuration of the Tiger 320 PMC's unique hardware and software capabilities.

## Input Signals & Sensors

### 4-20 mA or Sensor Direct

Unless sensors are located at a far distance, the greatest accuracy and best performance is usually obtained by connecting sensors directly to the Tiger 320, which will then function as the primary measurement device.

There are more than 120 Tiger compatible input signal conditioning modules, with the appropriate excitation outputs, to suit almost any type of sensor or combinations of up to 4 sensors.

In most cases, sensors with a 4-20 mA output are more costly, and when a separate 4-20 mA transmitter is used, signal conversion, drift, and calibration inaccuracies are introduced.

Some Tiger input modules combine direct sensor inputs with 4-20 mA inputs, enabling both local and far distant sensor inputs to be combined.

### Sensor Linearization or Compensation

The performance of many sensors can be greatly enhanced or expanded with linearization and or compensation. Sensors may be compensated for temperature, frequency, altitude, humidity and mechanical position, to name just a few parameters.

Tiger PMCs with 32 kilobits or more of memory provide up to four 32-point user defined linearization tables or one combined 125-point table.


Many compensation methods can be implemented with the standard cross channel math capabilities of the Tiger's 32-bit operating system. Complex three-dimensional compensation can also be implemented using the powerful macro programming capability.

The serial number and calibration date of a sensor can be loaded into the meter. The serial number, linearization tables, and compensation factors of a newly calibrated sensor can then be saved for future reloading, either serially through a PC or directly through the web via an Ethernet port.

Although there are numerous input modules with combinations of various input signals, some inputs such as watts or pH are provided on input modules dedicated to a single function. Combining these inputs with each other signals two or more Tiger meters can serially communicate, and be configured to share their data and processing resources.

## Display Options

Tiger PMCs have a large range of display options, including digital and alphanumeric LCDs, LEDs and Touch Panel HMIs.



### LED or LCD Displays

LED displays are a lower cost and popular display option. They operate over the largest temperature range, have better viewing angles and viewing distances, and have the longest operational life. However, red LEDs are difficult to read in direct sunlight without a shade hood and consume more power. Green LEDs and backlit LCD displays can be more easily read in direct sunlight.

The Tiger range can be ordered with red or green LEDs. LCD displays are also available, with or without backlighting.


### Numeric or Alphanumeric Displays

Generally, numeric displays are a lower cost option than alphanumeric displays. The Tiger range supports a full 7-segment numeric and 14-segment alphanumeric alphabet of English letters and Arabic numerals. Where complex text messaging or alarm annunciation is required, we recommend using the 14-segment alphanumeric option.

### Single or Multiple Display


The Tiger meter has four input channels and can be configured to display many different inputs or results. These can be viewed constantly on the operational display, or on demand in one of the view modes by pressing a button. Some applications require multiple values to be displayed simultaneously. With single, dual, or triple displays, and single displays with 51 or 101-segment bargraph combinations, we have a large range of display options to choose from.

Tiger meters can communicate with each other to share their data and processing resources and be stack or twin mounted to provide a wider range of display options.



### Push Button or Membrane Touch Pads

Tiger PMCs are shipped as standard with high usage hard plastic push buttons. An optional clear lens cover that opens on a cam hinge with a key lock can provide full NEMA 4 or IP65 dust and water proofing. Alternatively, an optional membrane touch pad faceplate can be ordered.



## Control Outputs & I/O Logic

### Electromechanical Relays or Solid State Control Outputs

Tiger PMCs have a wide selection of control outputs to choose from. The decision on which control output to choose depends on the current and the switching frequency.

Electromechanical relays are a popular choice for most control outputs. Tiger output modules are available with combinations of two 10 amp form C and two to six 5 amp form A relays that can be used to directly drive fractional HP motors or actuators.

The limitation of electromechanical relays is switching speed. If a relay needs to operate in less than 30 mS, or be cycled faster than .5 cpm, it is advisable to select an output module with solid state relays (SSR) or open collector outputs (OC), that can drive external high current SSRs.

**DECISION** **PID or On/Off Control**

Depending on the process to be controlled, either PID or on/off control should be selected. If the process variables are reasonably consistent, then the on/off control is generally more than adequate and easier to implement. Super smart setpoint control software supports many selectable functions, such as Hi or Lo activation, Latching, Hysteresis, Tracking, Register Resetting and 7 Multi-function internal Timers on all setpoints.

**PLANNING TIP** Control systems with large lag and lead times are not suitable for on/off control and tend to overshoot and undershoot. PID is needed to stabilize and control these systems. One of the many powerful setpoint functions provided by the Tiger 320 Operating System is single or dual PID.

**DECISION** **Retransmission 0-10V or 4-20mA**

Tiger PMCs can have an optional single (0-10 V or 0/4-20 mA) or dual (0-10 V) analog output module installed. The isolated 16-bit output is fully scalable and highly accurate. With a compliance of up to 500Ω at 20mA, the 4-20 mA output can be used over very long distances and still drive more than one output device, such as a PID controlled valve positioner.

**PLANNING TIP** The analog outputs can be reversed to output 20mA to 4/0 or 10 to 0VDC. They can be scaled across any portion of the digital range, up to full scale. The output can be programmed to swing 0 to 20mA or 0 to 10V in one digital count to drive external logic or SSRs as additional setpoints. Under Macro Program Control, the analog outputs can be programmed to produce pulses or even sinewaves.


**DECISION** **I/O Logic, Rear Panel or Breakout Box**

The Tiger Operating System has many built-in logic functions that can be used to develop sophisticated control systems. The Tiger PMC has three logic inputs/outputs available via the LOCK, HOLD, and CAPTURE pins, and three logic I/Os are available for input module use via pins D1, D2 and D3.

**PLANNING TIP** More complex I/O intensive applications require an opto-isolated I/O plug-in module, which supports six inputs and up to 16 outputs. This module can connect to an external Breakout Box that is DIN Rail mountable with screw terminal blocks. There are also compatible DIN Rail mounting electromechanical relays and SSR modules.

- 6 Inputs & 16 Outputs or 6 Inputs & 6 Outputs
- Fully Programmable

Connects to DIN Rail terminal block module with 3M IDC cable



**Serial Communication**

The easiest way to configure or program a Tiger PMC is with the free user-friendly Configuration or Macro Development Software. Serial I/O is provided via an optional Plug-in output carrier board, which supports RS-232 or RS-485 output modules. If serial I/O is not required by the application, the serial carrier board can be removed for reuse. The Tiger 320 Operating System supports several serial protocols, including ASCII, Modbus RTU and Print Mode (which includes a printer driver and support for direct meter to meter communications). Also supported is DeviceNet, which requires a special dedicated carrier board, and Ethernet (TCP/IP), which requires an external converter box.

**DECISION** **RS-232 or RS-485**

Except for DeviceNet, all serial communication modes supported by the Tiger can function with either RS-232 or RS-485. The limitations of RS-232 are that only one meter at a time can be connected to the serial port of a computer, and the

distance from the computer to the meter is limited in practical terms to around 30 meters (100 feet).

**PLANNING TIP** Up to 32 meters can be connected on an RS-485 bus. The differential current drive of the RS-485 bus ensures signal integrity in the most harsh environments to distances up to 1230 meters (4000 feet). However, RS-485 generally requires a special RS-485 output card to be installed in the computer or an external RS-232 to RS-485 converter has to be used.

**DECISION** **Select the Communication Mode Best Suited to Your Application:**

**Modbus (RTU)**

Modbus is widely used in industry. It has a large base, and most SCADA and HMI software packages support it. See also Modbus Wrapped in Ethernet (Modbus/TCP) below.




**PLANNING TIP** There are 100s of HMI Touch Panel Screens that are compatible with the Tiger 320 Modbus interface.

**ASCII**

The meter configuration utility program and the development software use the ASCII protocol. The ASCII protocol allows you to write your own driver for your own application via the development software and should provide the quickest development time.

**Print Mode**

This is an ASCII based printer driver output that enables the serial port to be directly connected to any serial printer with Epson compatibility. Printer output can be configured to occur from a setpoint or on demand, and can be date or time stamped.



**PLANNING TIP** The print mode can also be used for computer data logging applications. The meter can be connected directly to a computer, set up in Microsoft Hyperterminal mode, with the meter programmed to output directly into a Microsoft Excel spreadsheet format. (Also see Data Logging).

**Print Mode for Meter to Meter Communication**

Two or more Tiger PMCs can be connected together allowing data to be transferred from the master meter (in print mode) to the slave meter (in ASCII mode). This enables the meters to share input data and control output functions.

**Master Mode**

This mode is for use with macro programming to expand the meter to meter communication capability to multiples of Tiger PMCs. This is useful for building an entire system of Tiger PMCs, sharing information and control output resources.

**DECISION** **Ethernet**

Ethernet has become a popular automation and control protocol. We supply an ethernet output option and several external ethernet converters that are compatible with the serial outputs of Tiger PMCs.



**PLANNING TIP** **Ethernet ASCII Wrap** - The ethernet output carrier board option wraps the ASCII output into the Ethernet protocol, and provides a T-base 10/100 Ethernet output socket. This allows the Configuration Utility Program or the Macro Development Software to run over a standard Ethernet network. This enables the Tiger meter to be configured or macro programmed from anywhere in the world via the web.

**PLANNING TIP** Up to 32 Tiger PMCs can be connected by RS-485 to a single Ethernet Converter, which will support up to 32 separate IP addresses.

**PLANNING TIP** **Ethernet Modbus Wrap** - This converter accepts the Tiger PMC's modbus protocol and outputs Modbus/TCP through an Ethernet T-base 10 port. This has become a standard for Ethernet on the factory floor. Many SCADA and HMI software packages connect directly to Modbus/TCP.

**DeviceNet**

DeviceNet was originally developed by Allen Bradley to connect sensors from the factory floor to PLCs. It is a deterministic real-time system, typically used to connect to networks using Allen Bradley PLCs. An optional carrier board is required for DeviceNet which replaces the standard serial output with a dedicated DeviceNet output connector.

**Data Logging**

The Tiger 320 Operating System has built-in, sophisticated data logging software. Data logging can be triggered from the PROGRAM button, digital inputs, time or alarm functions. Up to 1MB of optional extra on-board memory provides a powerful, multichannel data capture and acquisition system.

Tiger PMCs can be configured to log in an endless loop, overwriting the oldest data first and utilizing the maximum amount of memory available. Similar to the Black Box on an aircraft, the data can be downloaded for analysis after a problem event occurs.

Data logging can be combined with an Ethernet converter to provide an individual Web Page with data that can be accessed by a browser over the internet.


**Real-time Clock**

The Tiger meter has an optional real-time clock with a 15 year lithium battery backup, ensuring that time information is not lost in the event of a power failure. It can be configured in 12 or 24-hour modes for printing and data logging applications.

Other applications of the real-time clock include activating a setpoint or control action at fixed times of the hour, day, week, month or year.


**Flash Card Memory Module**

For long term data logging, a Flash Card Memory Module that plugs in to the carrier board output socket is available. Flash Cards are available from 4 to 128 meg. They can be removed and read by a standard card reader, or the data can be downloaded through the serial port or over the internet with an Ethernet converter. The module also has an SSR setpoint output to trigger an external event.



**Configuration and Programming with a PC**

With a serial output module installed, Tiger 320 PMCs are most easily configured using the Tiger 320 Configuration Utility, which can be downloaded free from the web and run on any Windows-based PC. The utility also enables the user to access some special capabilities of the Tiger 320 which cannot be programmed manually by the front panel buttons.



**Code Blanking**  
Check only the codes you want to see

**Display Text Editing**  
Edit display text to suit your application

The Configuration Utility requires that an RS-232 interface board be installed in a Tiger 320 for programming. However, if the final application does not require a serial output, the RS-232 board can be easily removed, after programming is completed, and kept for future use.


When a Tiger 320 is to be used in a custom application, the utility enables all or any of the front panel programming functions to be disabled (code blanking). Customized descriptive text can also be entered to appear with any setpoint action or event.

Different configurations can be stored in a PC for fast downloading into a meter by the user. Custom configurations can also be issued a serial number and pre-loaded at the factory.

**Development Software**

**Custom Macro Programming**

This powerful, easy to use development system enables programs to be written in BASIC, utilizing any combination of the hundreds of functions and thousands of registers embedded in the Tiger 320 Operating System. When your Basic program is compiled into the Tiger 320 Macro-language it is error checked and optimized. There are also numerous off-the-shelf application specific programs available. Many only need the blanks to be filled in to use them and do not require any knowledge of BASIC programming.



Macro in the writing stage

Macros are useful when implementing any specialized control system that cannot be achieved by the standard configuration capability of the Tiger 320 Operating System. Using the development software, functions can be altered or added in a standard meter to perform the required job. This may typically include logic sequencing functions and mathematical functions.


Developing a Macro is much easier and quicker than programming a PLC, because the basic code required to customize the Tiger meter is considerably less than the ladder logic programming required for PLCs. This is due to the hundreds of functions built into the Tiger meter that can be manipulated or invoked by a macro, to fulfill the requirements of almost any application.

Scrolling annunciator messages can be programmed to appear with any setpoint activation, selected events or logic inputs. Easy to read, plain text prompts can be programmed to replace the manual programming codes and provide a user-friendly interface for any custom application.





# Block Diagram of the Tiger 320 Software and Hardware Structure



# The Easiest and Fastest Way to Configure the Tiger 320 is to Use a PC with the Free Downloadable Configuration Utility Program

The diagrams and instructions provided in this data sheet / user manual are intended to enable the Tiger meter to be configured and programmed manually using the front panel buttons. A system of Programming Codes is required to facilitate this type of manual programming and these are explained in detail with diagrams and examples.

However, when the Tiger meter is configured and programmed via the optional RS-232 serial port and a PC using the Configuration Utility, the system of Programming Codes is bypassed. The Configuration Utility enables all the programming options to be clearly identified by their functions for direct on-screen selection. The Configuration Utility requires that an RS-232 interface board be installed in a Tiger 320 for programming. However, if the final application does not require a serial output, the RS-232 board can be easily removed, after programming is completed, and kept for future use.


The Configuration Utility Program (which may be freely downloaded from the web) is designed to simplify and speed up the configuration and programming of any Tiger 320. Pull down menus facilitate the selection of different options and the assignment of values. A "Help" explanation is provided just by holding the cursor over any function box.

The configuration utility enables the user to access some special capabilities of the Tiger 320 which cannot be selected manually by the front panel buttons.

Table 1	Table 2	Table 3	Table 4
Date (YYMM): 9937	Date (YYMM): 9937	Date (YYMM): 9937	Date (YYMM): 9937
Serial No. 1	Serial No. 2	Serial No. 3	Serial No. 4
Input	Input	Input	Input
Output	Output	Output	Output
1 0 0	1 0 0	1 0 0	1 0 0
2 10000 10000	2 10000 10000	2 10000 10000	2 10000 10000
3 20000 20000	3 20000 20000	3 20000 20000	3 20000 20000
4 30000 30000	4 30000 30000	4 30000 30000	4 30000 30000
5 40000 40000	5 40000 40000	5 40000 40000	5 40000 40000
6 50000 50000	6 50000 50000	6 50000 50000	6 50000 50000
7 60000 60000	7 60000 60000	7 60000 60000	7 60000 60000
8 70000 70000	8 70000 70000	8 70000 70000	8 70000 70000
9 80000 80000	9 80000 80000	9 80000 80000	9 80000 80000
10 90000 90000	10 90000 90000	10 90000 90000	10 90000 90000
11 100000 100000	11 100000 100000	11 100000 100000	11 100000 100000
12 110000 110000	12 110000 110000	12 110000 110000	12 110000 110000
13 120000 120000	13 120000 120000	13 120000 120000	13 120000 120000
14 130000 130000	14 130000 130000	14 130000 130000	14 130000 130000
15 140000 140000	15 140000 140000	15 140000 140000	15 140000 140000

## Easy Installation of Linearization Tables

The configuration utility facilitates the storage and downloading of complex linearization tables. Tables can be created in any mathematical or spreadsheet program, and copied into the utility. Linearization tables can be created to precisely match a particular sensor so that they can be installed and downloaded as part of an annual calibration procedure.



## Code Blanking

When a custom configuration is created for any specialized application, the Tiger 320 can be programmed to blank out and disable all or any manual programming codes that you do not wish the user to be able to view or access by de-selecting them in the appropriate check box.

## Display Text Editing

The meter can be programmed to display customized text to appear for any setpoint or event to suit any application requirements.

**Source For Setpoints 1-6**  
 OFF Primary Display  
 Result Channel 1  
 Channel 2  
 Channel 3  
 Channel 4  
 Totallator 1  
 Totallator 2  
 Peak  
 Valley  
 Tare  
 Setpoint 1  
 Setpoint 2  
 Setpoint 3  
 Setpoint 4  
 Setpoint 5  
 Setpoint 6  
 PID 1  
 PID 2  
 Register

**Latching For Setpoints 1-6**  
 None  
 Latch ON  
 Latch OFF

**Activation For Setpoints 1-6**  
 Above  
 Below

**Mode For Setpoints 1-6**  
 OFF  
 Normal  
 One Shot  
 Pulse Repeat

**Timer For Setpoints 1-6**  
 OFF  
 Normal  
 One Shot  
 Pulse Repeat

**Reset Mode**  
 Reset Value  
 Constant  
 Input SP+Const.  
 Dest.+Const.  
 Display  
 Result Channel 1  
 Channel 2  
 Channel 3  
 Channel 4  
 Totallator 1  
 Totallator 2  
 Peak  
 Valley  
 Tare  
 Setpoint 1  
 Setpoint 2  
 Setpoint 3  
 Setpoint 4  
 Setpoint 5  
 Setpoint 6  
 PID 1  
 PID 2  
 Register

## Easy Setpoint Configuration

The Tiger 320 supports an incredible range of setpoint options and functions. The utility makes it quick and easy to select and download any combination you may require.

## Configuration Data Copying and Loading

The configuration utility program allows you to store a record of a meter's configuration for later referral, or for the restoration of a desired configuration. Macros can be combined with a configuration file so they can be downloaded together and locked at the same time. When a file is locked after downloading, it cannot be copied. It can only be erased and reloaded from a master file.

Also included is the ability for the user to make notes about the configuration that can be stored as part of the file.

# Never Before has the Customization of such a Powerful Measurement, Control and Automation Product been Made so Fast, Free and Easy

The Tiger 320 Macro Development System is so power packed and feature rich that you can build a completely custom designed controller in 1/50th of the time it would take to program a microprocessor or a PC, and 1/20th of the time it can take to program a PLC.

Quickly convert any special metering or control and automation idea into your own proprietary product, CE approved and ready to ship in days, with custom multicolor faceplates, labels, shipping boxes and instruction manuals.

This powerful, easy to use Development System can be downloaded free from the web. It enables programs to be written in BASIC, which can utilize any combination of the hundreds of functions and thousands of registers embedded in the Tiger 320 Operating System.

When your BASIC program is compiled into the Tiger 320 Macro-language it is error checked and optimized. When your Macro is downloaded into a Tiger 320 and locked, it is locked forever. It cannot be read or duplicated, it can only be erased. There is no back-door access. A Tiger 320 running your Macro will remain your exclusive proprietary product.


There is also a growing library of off-the-shelf application specific macro programs available. Many only need the blanks to be filled in to use them and this does not require any knowledge of BASIC. The source code is provided with these programs so they can easily be customized and/or integrated into any proprietary application-specific Macro.

On request, any custom Macro can be issued a serial number and pre-installed at the factory to operate on power-up.




Scrolling annunciator messages can be programmed to appear with any setpoint activation, selected events or logic inputs. Easy to read, plain text prompts can be programmed to replace the manual programming codes and provide a user-friendly interface for any custom application.

### Tiger Development System - Code Writing Screen




Tiger Development System screen showing Macro being written.




Double clicking on register label in the left hand side frame automatically inserts the function in the code window at the cursor insertion point.

Tiger Development System screen showing the Macro code being compiled successfully.




Tiger Development System screen showing the compiled Macro being downloaded into a Tiger 320 Series PMC.




<b>32-Bit Operating System</b> .....	<b>4</b>	<b>Clock/Timer</b>	
<b>Analog Output / Analog Retransmission</b> .....	<b>21-22</b>	Configuration .....	31, 34, 35
Calibration of Analog Output .....	21	Optional Real-time Clock .....	4
Dual (0-10V) Analog Output .....	21	Real-time Clock Configuration .....	31, 34, 35
Location of Analog Output Module .....	47	Real-time Clock Date .....	37
Pinout of Analog Output .....	46	Time Stamp .....	37
Scaling of Analog Output .....	21, 22	<b>Component Layout &amp; External Devices</b> .....	<b>47-48</b>
Select Source for Analog Output .....	21	Modular Construction .....	47
<b>Auto Zero Maintenance for Weighing Applications</b> .....	<b>22</b>	Component Layout .....	48
Set Parameters for CH1, CH2, CH3 & CH4 .....	21	<b>Configuration and Programming from a PC</b> .....	<b>4, 8</b>
<b>Averaging - Digital Filtering</b> .....	<b>22</b>	<b>Configuration Utility Program</b>	
Set Parameters for CH1, CH2, CH3 & CH4 .....	21	Code Blanking and Display Text Editing .....	10
<b>Block Diagram of Software &amp; Hardware</b> .....	<b>9</b>	Configuration Data Copying .....	10
<b>Brightness (contrast) Display</b> .....	<b>20</b>	Installation of Linearization Tables .....	10
<b>Calibration</b> .....	<b>21-24</b>	Setpoint Configuration .....	10
Calibration Thermocouple or RTD .....	21	<b>Connections</b>	
Manual Calibration .....	23	Carrier Board Output Pinouts .....	46
Single-Point Calibration.....	23	Connector Pinouts .....	45
Two-Point Calibration .....	23	DeviceNet .....	46
<b>Case Dimensions</b> .....	<b>60</b>	External Devices .....	48
Modular Construction .....	47	Ordering Information, Connectors .....	58
Other Case Sizes .....	3, 4	Rear Panel Pinout Diagram .....	45
<b>Channel 1 Settings</b> .....	<b>31-32</b>	<b>Controls &amp; Indicators</b> .....	<b>14-15</b>
32 Point Linearization .....	32	Down Button .....	14
Analog Input Signal Sample Rate.....	31	Error Message .....	15
Counter/Resident Timer/Clock .....	31	LCD Display .....	14
Measurement Task .....	31	Program Button.....	14
Post Processing .....	32	Program Lockout Switch .....	15
Print Mode.....	32	Scrolling Display Text Messaging .....	14
Sampling Rate .....	31	Setpoint Lockout Switch .....	15
Serial Mode.....	32	Seven Segment LCD Displays .....	14
Smart Input Module .....	31	Up Button .....	14
<b>Channel 2 Settings</b> .....	<b>33</b>	<b>Control Outputs</b> .....	<b>6-7</b>
<b>Channel 3 Settings</b> .....	<b>34</b>	Electromechanical Relays	
<b>Channel 4 Settings</b> .....	<b>35</b>	or Solid State Control Outputs .....	6
<b>Channel 1 &amp; Channel 2 Results Processing</b>		I/O Logic, Rear Panel or Breakout Box.....	7
32 Point Linearization .....	36	PID or ON/OFF Control .....	7
Maths Functions .....	36	Retransmission 0-10V or 4-20mA.....	7
<b>Code 1 - Display Configuration</b> .....	<b>25-30</b>	<b>Custom Macro Programming</b>	
Configure Data Source Procedure .....	27	Macro Compiling and Loading .....	11
Configure Display Format Mode Procedure .....	28	<b>Data Logging</b> .....	<b>4, 8, 37</b>
Configure Last Digit Text Char. Procedure .....	29	Downloading Logged Data from Meter.....	37
Configure Update at Sample Rate Procedure .....	30	Flash Card Memory Module .....	8
Data Source - 2nd Digit [X5X] .....	25	Printing Logged Data .....	37
Display Format - 2nd Digit [X6X] .....	25	Real-time Clock.....	8, 37
Display Functions Mode .....	25	<b>Development Software</b>	
Manual Loader Mode .....	25	When to Use Macros .....	8
Text Character - 2nd Digit [X7X] .....	25	<b>DeviceNet</b> .....	<b>8, 46</b>
Update Display at Selected Sample Rate.....	25	<b>Digital Input Pins</b> .....	<b>37</b>
<b>Code 2 - Channel 1 Measurement Task</b>		<b>Display Brightness Setting</b> .....	<b>20</b>
<b>and Sampling Rate</b> .....	<b>31</b>	<b>Display Functions</b> .....	<b>25-30</b>
<b>Code 3 - Channel 1 Post Processing</b>		Data Source .....	27
<b>and Serial Mode Functions</b> .....	<b>32</b>	Display Format and Decimals .....	28
<b>Code 4 - Channel 2 Measurement Task</b>		Display Rounding .....	28
<b>and Sampling Rate</b> .....	<b>33</b>	Last Digit Text Character.....	29
<b>Code 5 - Channel 3 Functions</b> .....	<b>34</b>	Other Display Formats .....	4
<b>Code 6 - Channel 4 Functions</b> .....	<b>35</b>	Update at Sample Rate .....	30
<b>Code 7 - Result Processing</b> .....	<b>36</b>	<b>Display Options</b>	
<b>Code 8 - Data Logging &amp; Print Mode</b> .....	<b>37</b>	LED or LCD Displays .....	6
<b>Code 9 - Functions for Digital Input Pins</b> .....	<b>37</b>	Numeric or Alphanumeric Displays.....	6
<b>Code Blanking</b> .....	<b>19-20</b>	Push Button or Membrane Touch Pads .....	6

Remote Display .....	6	Channel 1 .....	31
Single or Multiple Displays .....	6	Channel 2 .....	33
<b>Faceplates</b>		<b>Print Mode .....</b>	<b>7, 32</b>
Custom Faceplates .....	59	<b>Programming Codes.....</b>	<b>17-18</b>
Optional Caption Sheets .....	59	<b>Programming Conventions .....</b>	<b>16</b>
Custom Faceplate Design Template .....	59	<b>Programming via PC .....</b>	<b>4, 10-11</b>
<b>Filtering</b>		<b>Registers</b>	
<i>See Averaging Samples &amp; Averaging Window</i>		Registers That Can Be Selected .....	44
<b>Front Panel Controls .....</b>	<b>4, 14-15</b>	Registers That Should Not Be Selected .....	44
<b>Front Panel Programming Codes .....</b>	<b>17-18</b>	Resetting and Incrementing Using Setpoints .....	44
Main Programming Mode .....	17	<b>Relay &amp; Logic Output Modules .....</b>	<b>46</b>
On Demand Modes.....	18	<b>Serial Communication .....</b>	<b>5, 7-8</b>
Setpoint Programming Mode .....	17	ASCII.....	7
View Modes .....	18	Configuration.....	32
<b>Functional Diagram .....</b>	<b>45</b>	DeviceNet .....	8
<b>General Features .....</b>	<b>1</b>	Ethernet .....	7
<b>HMI Touch Panel Graphic Displays .....</b>	<b>7</b>	Master Mode.....	7
<b>Hysteresis and Deviation.....</b>	<b>39-40, 42</b>	Modbus .....	7
<b>Initial Setup Procedures.....</b>	<b>19-20</b>	Pinouts .....	46
Code Blanking and Macro Check .....	19-20	Print Mode.....	7
Model and Software Code Version Check .....	19	RS-232 or RS-485 .....	7
<b>Input Signal Conditioning Modules .....</b>	<b>5, 49-55</b>	<b>Setpoint Programming Mode.....</b>	<b>38-43</b>
Input Module Component Glossary .....	55	Data Logging.....	39
Input Module Index .....	49	Data Printing to PC.....	39
Input Modules .....	50-54	Data Printing to Serial Printer.....	39
Modular Position .....	47	Display Flashing .....	39
Ordering Information, Input Modules .....	56-57	Hysteresis or Deviation.....	39-40, 42
<b>Input Signals &amp; Sensors</b>		Level 1 - Basic Mode - Prog. Procedures .....	41
4-20mA or Sensor Direct .....	6	PID Control Settings .....	39, 42
Sensor Linearization or Compensation.....	6	Real-time Clock Option.....	39
<b>I/Os (Opto Isolated &amp; Logic Ports) .....</b>	<b>5, 48</b>	Real Time Control Modes .....	40
<b>Linearization</b>		Relay Energize Functions.....	39
Channel 1 Temperature Sensors .....	31	Relay Output Modules .....	38
Channel 1 User Loaded Tables.....	32	Setpoint & Relay Control Settings .....	38, 42
Channel 2 Temperature Sensors		Setpoint Activation Source .....	39
and User Loaded Tables .....	33	Setpoint Activation Values.....	38
Channel 3 Temperature Sensors		Setpoint Latching .....	39
and User Loaded Tables .....	34	Setpoint Reset & Trigger.....	39, 43
Channel 4 Temperature Sensors		Setpoint Tracking.....	39
and User Loaded Tables .....	35	Timer Modes.....	39, 43
Result of CH1 & CH2 User Loaded Tables.....	36	<b>Smart Input Modules</b>	
Table Settings .....	22, 36	Setting Up .....	31
<b>Literature Overview</b>		<b>Supplements</b>	
Model Specific Data Sheets / User Manuals .....	3	<i>See Literature Overview</i>	
Other Tiger 320 Series Related Software.....	3	<b>Table of Contents .....</b>	<b>1</b>
Programming Code Sheet .....	3	<b>Timers .....</b>	<b>5, 39</b>
Supplements to Data Sheets / User Manuals.....	3	Configuration.....	31, 34, 35
<b>Macros .....</b>	<b>4, 8, 11</b>	Delay Settings.....	43
Macro Check.....	19-20	Modes .....	40
<b>Manual Loader .....</b>	<b>25</b>	<b>Totalizers</b>	
<b>Maths Function</b>		Setting.....	21-22
Cross Channel Maths .....	9, 36		
Result Processing.....	36		
<b>Modbus .....</b>	<b>7, 22</b>		
<b>Model Type Check.....</b>	<b>19</b>		
<b>On Demand Functions .....</b>	<b>21</b>		
<b>Ordering Information .....</b>	<b>56-58</b>		
<b>Panel Cutout .....</b>	<b>60</b>		
<b>PID Control Settings.....</b>	<b>39, 42</b>		
<b>Power Supply .....</b>	<b>5, 45</b>		
<b>Prescaling</b>			

**Front Panel Controls and Indicators**



Optional Membrane Touch Pad Faceplate  
Part Number: 76-DI60X-N4



**Display with Faceplate and Bezel**

**Program Button**

While programming, pressing the **P** button saves the current programming settings and moves to the next programming step.

You can move through the programming codes using the program button. The codes you pass are not affected, unless you stop and make changes using the **↑** or **↓** buttons.

Pressing the **P** and **↑** button at the same time initiates the **main programming mode**. To save a new configuration setting and return to the operational display, press the **P** button once and then press the **P** and **↑** button at the same time.

Pressing the **P** and **↓** button at the same time initiates the **setpoint programming mode**. To save a new configuration setting and return to the operational display, press the **P** button once and then press the **P** and **↓** button at the same time.

See *Display with Faceplate and Bezel* diagram.

**Up Button**

When setting a displayed parameter during programming, press the **↑** button to increase the value of the displayed parameter.

When in the operational display, pressing the **↑** button initiates a viewing mode that allows you to view the readings on **channels 1 and 3, setpoints 1, 3, and 5, peak, and total 1**. Once into the viewing routine, pressing the **↑** button moves through each displayed parameter.

See *Display with Faceplate and Bezel* diagram.

**Down Button**

When setting a displayed parameter during programming, press the **↓** button to decrease the value of the displayed parameter.


When in the operational display, pressing the **↓** button initiates a viewing mode that allows you to view the readings on **channels 2 and 4, setpoints 2, 4, and 6, valley, and total 2**. Once into the viewing routine, pressing the **↓** button moves through each displayed parameter.

See *Display with Faceplate and Bezel* diagram.

**Seven Segment LCD Displays**

The six, seven segment LCD displays are used to display the meter input signal readings.

They also display the programming codes and settings during programming.



**Display PCB without Faceplate and Bezel**

**LCD Display**

The meter has a 5-digit, 7-segment, 0.56" (14.2 mm) standard LCD numeric display. The LCD displays are used to display the meter input signal readings. They also display the programming codes and settings during meter programming.

**Display Text Editing with 7 Segment Alphanumeric Display Characters**

Display text, such as setpoints, can be easily edited to suit your application, by connecting the meter to a PC running the free downloadable Configuration Utility program.

**For Example:**

Instead of [SP\_1]



could be used for  
TANK LOW

Instead of [SP\_2]



could be used for  
BRAKE OFF

**Scrolling Display Text Messaging**


Scrolling display text messaging can be configured to run but requires a simple compiler generated macro.



**Display Text Characters**

The following text characters are used with the 7-segment display.

**7-SEGMENT DISPLAY CHARACTERS**



## Program Lockout Switch

When the PROGRAM LOCKOUT switch is set to position 2, all programmable meter functions can be changed.

When set to the ON position, the PROGRAM LOCKOUT switch prevents any programming changes being made to the meter. If programming is attempted, the meter displays 'LOC'. The ON position allows programming parameters to be viewed but not changed.

See *Display without Faceplate and Bezel* diagram.

## Setpoint Lockout Switch

When the SETPOINT LOCKOUT switch is set to position 1, the setpoints can be programmed. Once the setpoint values have been entered and the SETPOINT LOCKOUT switch set to the



Display Showing [Err] Message

ON position, the setpoints can be viewed but not changed.


See *Display without Faceplate and Bezel* diagram.

## Error Message [Err]

Error messages usually occur during calibration procedures. The three most likely causes of an error message are:

- 1) The full scale and zero signals were too similar.  
Note, the high input (full scale) signal must be at least 1000 counts greater than the low input (zero) signal (positive and negative values are allowed).
- 2) The scaling requirement exceeded the capability of the meter (-199999 to +999999).
- 3) No input signal present, or incorrect connections.


## Rear Panel External Switched Inputs



Rear Panel

## Lock Pin

By configuring Code 9 to [XX0], connecting the LOCK pin (pin 8 on the main PCB) to the COMMON pin (pin 11 on the main PCB), locks out the main and setpoint programming modes. All meter programming codes and setpoints can be viewed but not changed.



Display Showing [Lock] Message

The main programming mode can be entered, but only the brightness setting adjusted. After adjusting the brightness setting, pressing the [P] button displays [LoCK].

The LOCK pin can also be configured in Code 9 to carry out the following functions (see *Meter Programming Codes* on Page 17):

- Reset channel 1 [XX1].
- Reset channel 2 [XX2].
- Reset channel 3 [XX3].
- Reset channel 4 [XX4].
- Reset tare [XX5].
- Reset total 1 [XX6].
- Unlatch (de-energize) all setpoints [XX7].

## Hold Pin

Configure Code 9 to [X0X]. When the HOLD pin (pin 9) is connected to the COMMON pin (pin 11) the displayed reading is frozen. However, A/D conversions and all control functions continue and as soon as pin 9 is disconnected from pin 11 by the switch, the updated reading is instantly displayed.

The HOLD pin can also be configured in Code 9 to carry out the following functions (see *Meter Programming Codes* on Page 17):

- Reset channel 1 [X1X].
- Reset total 1 and total 2 [X2X].
- Reset total 2 [X3X].
- Reset peak and valley [X4X].
- Reset tare [X5X].
- Set tare [X6X].
- Unlatch (de-energize) all setpoints [X7X].

## Test Pin

Configure Code 9 to [00X]. When the TEST pin (pin 10) is connected briefly to the COMMON pin (pin 11) all segments of the display light up. Six eights and six decimal points (8.8.8.8.8.8.) are displayed for a short period. The microprocessor is also reset during this time, losing all RAM settings such as peak and valley, and any digital input pin settings set up in Code 9.

The TEST pin can also be configured in Code 9 to carry out the following (see *Meter Programming Codes* on Page 17):

- Reset counter channel 1 and total 2 at power-up [1XX].
- Reset counters, CH1, CH2, CH3, CH4, total 1, and total 2 at power-up [2XX].
- Reset total 1 and total 2 at power-up [3XX].

## Capture Pin


When the CAPTURE pin (pin 12) is connected to the COMMON pin (pin 11), the CAPTURE pin can be programmed for setpoint/relay activation or macro control applications in the setpoint control settings mode of the setpoint programming mode [SPC-X] [X2X].

## Common Pin

To activate the LOCK, HOLD, TEST and CAPTURE pins from the rear of the meter, the respective pins have to be connected to the COMMON pin (pin 11).

# Front Panel Push Button Configuration and Setup for Programming Conventions

The meter uses a set of intuitive software codes to allow maximum user flexibility while maintaining an easy programming process. To configure the meter's programming codes, the meter uses the three right-hand side display digits. These are known as the first, second, and third digits and can be seen in the diagram opposite.




To explain software programming procedures, diagrams are used to visually describe the programming steps. The following conventions are used throughout the range of Tiger 320 Series document diagrams to represent the buttons and indicators on the meter, and the actions involved in programming the meter:

**Symbol**                      **Explanation**

This symbol represents the **OPERATIONAL DISPLAY**. After the meter has been powered up, the display settles and indicates the input signal or the result of a math function to the meter. This is known as the operational mode and is generally referred to as the operational display throughout the documentation.

**All programming modes are entered from this level.**

**P** This symbol represents the **PROGRAM** button. In a procedure, pressing the program button is always indicated by a **left hand**. A number indicates how many times it must be pressed and released, or for how long it must be pressed before releasing.



This symbol represents the **UP** button. Shown in a diagram, pressing the UP button is always indicated by a **right hand**.

This symbol represents the **DOWN** button. Shown in a diagram, pressing the DOWN button is always indicated by a **right hand**.

Where two right hands are shown on the same diagram with the word **OR** between them, this indicates that both the and buttons can be used to adjust the display: UP for increase, DOWN for decrease.

**[Span]**                      Text or numbers shown between square brackets in a description or procedure indicate the programming code name of the function or the value displayed on the meter display.  
**[10000]**


Programming procedures are graphic based with little descriptive text.

Each procedure shows a number of meter panel displays running in procedural steps from the top to the bottom of the page.

If need be, the procedure may run into two columns with the left column running down the page and continuing at the top of the right-hand column. Each action performed by the user is shown as a numbered step.


Each procedural step shows the meter display as it looks before an action is performed. The hand or hands in the procedural step indicate the action to be performed and also how many times, or for how long, the button is to be pressed.

For example, the diagram below shows the meter in the operational display. With a left hand pressing the button and a right hand pressing the button, the user is entering the **main programming mode**. This is indicated by the next diagram displaying [bri] and [5]. This is the display brightness mode and is the first sub-menu of the main programming mode.




Where a left and right hand are shown on separate buttons on the same diagram, this indicates that the buttons must be pressed at the same time.

The only exception to this rule is when carrying out the *Model and Software Code Version Check*.



When two displays are shown together as black on grey, this indicates that the display is toggling (flashing) between the name of the function and the value or configuration setting.

Where a number is not definable, the default setting [000] is shown.



If an X appears in place of a digit, this means that any number displayed in that digit is not relevant to the function being explained.



# Front Panel Programming Codes

The meter's manual programming codes are divided into two modes: the **main programming mode**, and the **setpoint programming mode** (See diagram below). Each mode is accessible from the operational display.




## Programming Tip

The easiest and fastest way to configure the Tiger 320 is to use a PC with the free downloadable configuration utility program. (see page 10)

## Main Programming Mode

The main programming mode provides access to program all meter functions, except setpoints.



To enter or exit the Main Programming Mode, press **[P]** and **[↑]** at the same time

To enter or exit the Setpoint Programming Mode, press **[P]** and **[↓]** at the same time

### Main Programming Mode

- [bri]** Display Brightness
  - [P]**
  - [CAL]** Calibration Modes for Input and Output
  - [P]**
  - [CodE\_1]** Code 1 – Display Configuration
  - [P]**
  - [CodE\_2]** Code 2 – CH1 Measurement Task & Sampling Rate
  - [P]**
  - [CodE\_3]** Code 3 – CH1 Post Processing & Serial Mode Functions
  - [P]**
  - [CodE\_4]** Code 4 – CH2 Measurement Task & Sampling Rate
  - [P]**
  - [CodE\_5]** Code 5 – CH3 Functions
  - [P]**
  - [CodE\_6]** Code 6 – CH4 Functions
  - [P]**
  - [CodE\_7]** Code 7 – Result Processing
  - [P]**
  - [CodE\_8]** Code 8 – Data Logging & Print Mode
  - [P]**
  - [CodE\_9]** Code 9 – Functions for Digital Input Pins
  - [P]**
  - [CodE10]** Code 10 – Bargraph Setup
- Code 10 applies to Tiger 320 Series meters with bargraph displays only. See data sheets for DI-50B51, FI-B101D50, and GI-50B101.



## Programming Tip

### Save Code Settings & Exit

To save a new main programming mode configuration setting and return to the operational display at any point, press the **[P]** button once.

Then press the **[P]** and **[↑]** button at the same time to exit.



## Programming Tip

### Save SP Settings & Exit

To save a new setpoint configuration setting and return to the operational display at any point, press the **[P]** button once.

Then press the **[P]** and **[↓]** button at the same time to exit.

### Setpoint Programming Mode

#### Setpoint Activation Values Mode

Enter these menus to adjust SP activation values

- [SP\_1]** Setpoint 1
- [P]**
- [SP\_2]** Setpoint 2
- [P]**
- [SP\_3]** Setpoint 3
- [P]**
- [SP\_4]** Setpoint 4
- [P]**
- [SP\_5]** Setpoint 5
- [P]**
- [SP\_6]** Setpoint 6

#### Setpoint & Relay Control Mode Settings

Enter these menus to configure SP control values


- [SPC\_1]** Setpoint 1
- [P]**
- [SPC\_2]** Setpoint 2
- [P]**
- [SPC\_3]** Setpoint 3
- [P]**
- [SPC\_4]** Setpoint 4
- [P]**
- [SPC\_5]** Setpoint 5
- [P]**
- [SPC\_6]** Setpoint 6

The *Setpoint and Relay Control Settings* diagram on Pages 42 and 43 shows the three digit configuration settings that are applied individually to each setpoint.


See Page 41 for an example procedure to configure a setpoint for simple relay functions.




**View Modes**

While in the operational display, pressing the  button allows you to view but not change the following parameters:


- Channel 1.
- Channel 3.
- Setpoint 1.
- Setpoint 3.
- Setpoint 5.
- Peak (of CH1).
- Total 1 (total of CH1).

While in the operational display, pressing the  button allows you to view but not change the following parameters:

- Channel 2.
- Channel 4.
- Setpoint 2.
- Setpoint 4.
- Setpoint 6.
- Valley (of CH1).
- Total 2 (total of CH2).





**On Demand Modes**

The meter can be programmed to activate the following functions on demand by pressing the  button for 4 seconds:

- Tare.
- Single-point calibration.
- Two-point calibration.
- Primary input compensation.
- Manual loader (manual offset).
- Print.

The on demand function is selected in the calibration mode.



After configuring an on demand function in the **Calibration On Demand Mode**, press the  button for 4 seconds to activate one of the following selected on demand modes.

For a full breakdown of all programming codes, see the *Tiger 320 Series Programming Code Sheet (NZ101)*. See page 3 for more information.

# Initial Setup Procedures

Before configuring the meter, carry out the following meter configuration checks:

- Model and software code version check.
- Code blanking and macro check.

After powering-up the meter, check the model and software code version number and note this in your user manual.

## Model and Software Code Version Check


The meter model and software code version number can be checked at any time while in the operational display using the following procedure.

**START HERE**

### MODEL & SOFTWARE CODE VERSION CHECK


#### Step 1

Press and hold the and buttons




#### Step 2

While holding both buttons, press the Prog. button then release all three buttons



#### Step 3

The displays toggle three times. If a macro is installed and turned on, the customer ID and the macro ID scroll across the display before returning to the operational display.



Model No: .....  
 Software Version No: .....  
 Customer ID: .....  
 Macro ID: .....



### Programming Tip

The *Model and Software Code Version* checking procedure can be performed at any time without interfering with other configuration settings.

## Code Blanking and Macro Check

Tiger 320 Series meters have the ability to hide (blank out) all or some programming codes, making them tamper-proof. This can only be done using the Meter Configuration program.

With code blanking turned ON, all main and setpoint codes that have been blanked out during factory programming are hidden, preventing them from being reprogrammed. Any codes that have not been blanked out are still visible and can be reprogrammed.

Turning code blanking OFF means all meter programming codes are visible when you enter the programming modes and can be reprogrammed.

A macro is a set of commands that run automatically when the meter is powered up. We have a growing library of macros to suit a wide range of standard customer applications.

Macros can be installed in the meter at the factory during initial programming or by the customer at some later date. Macros are written and compiled using the BASIC Compiler program, and loaded into the meter using either the BASIC Compiler program or the Meter Configuration program.

Turning the macro OFF means that the meter will not perform the automatic commands pre-programmed to run with the macro.

Unless requested to blank out all or some programming codes and/or run a macro, we will program the meter in the code blanking OFF and macro OFF (default) setting.


To turn the code blanking and macro settings from ON to OFF:

**START HERE**

### CODE BLANKING & MACRO CHECK PROCEDURE


#### Step 1

Press and hold the and buttons




#### Step 2

While holding both buttons, press the Prog. button.




#### Step 3

Release the the and buttons and hold the Prog. button for approx. 1 sec then release



#### Example

NOTE: Unless otherwise requested, the factory default setting is oFF



#### Step 4

Press the button to switch code blanking OFF

**Code Blanking & Macro Check Procedure** continued on next page (Step 5)

continued from Step 4



**Step 5**


Press the Prog. button.



**Example**



NOTE: Unless otherwise requested, the factory default setting is OFF



**Step 6**

Press the  button to switch the macro OFF



**Step 7**

Press the Prog. button.



Operational Display



**Programming Tip**

Code Blanking and Macro ON/OFF settings revert to the meter's original configuration settings when the meter is powered off and on.

**Display Configuration**

Once you have read the data sheet and related supplements, and installed and powered-up the meter, configure the display to suit its designated application.

**Display Brightness (Contrast) Mode**


The **display brightness (contrast) mode** is accessed when entering the main programming mode. It allows you to adjust the brightness of the display LCDs without interfering with other configuration settings. It is always available, even with the PROGRAM LOCK switch set to ON, or the external LOCK pin connected to the COMMON pin, locking out the programming modes.

The contrast can be set between 0 and 7, with 0 being dull and 7 being bright. The default setting is 5.


**Example Procedure:**

Configure the contrast setting to 7 (bright).


**Step 1**



**Step 2**



**Step 3**



**Programming Tip**

The *Display Brightness (Contrast)* setting procedure can be performed at any time without interfering with other configuration settings by entering the main programming mode.

# [CAL] - Calibration Modes for Input and Output

The Tiger 320 Series meter has an extremely powerful set of input and output calibration modes. See diagram below.

## Functions Activated by **P** Button Mode


In this mode the meter can be programmed to activate one of the following on demand functions by pressing the **P** button while in the operational display:

- On Demand TARE.
- On Demand Single-point Calibration (requires single input source).
- On Demand Two-point Calibration (requires dual input source).
- On Demand Primary Input Compensation Mode.
- On Demand Manual Loader Mode.

## Calibration Modes

The following calibration modes are available:

- Manual Calibration (requires NO input source).
- **Two-point Calibration (requires dual input source).**  
This is the calibration mode generally used to calibrate the meter for most applications. An example procedure has been included.
- Calibrate Thermocouple (requires K type thermocouple input source).
- Calibrate RTD (requires RTD 385 input source).
- Calibrate Smart Input Module (not available on all input modules).
- Calibrate Analog Output (requires multimeter connected to pins 16 and 17).



## Related Calibration Functions

The following functions are also configured in the calibration mode. See *Advanced Calibration and On Demand Mode Supplement (NZ203)* for further calibration details. (See page 3 for more information).

## Serial Communications Properties

Selecting [CAL][20X] enters the Serial Communications Properties Mode.

This mode allows you to configure the serial communications output module baud rate, parity, time delay, and address settings.

See the **calibration modes** diagram on Page 21 showing a breakdown of 1st, 2nd, and 3rd digits.

Also see the *Serial Communications Module Supplement (NZ202)* for further details on the serial communications module. (See page 3 for more information).

## Set Auto Zero Maintenance

Selecting [CAL][21X] enters the Set Auto Zero Maintenance Mode.

This mode allows you to configure auto zero maintenance settings for weighing applications applied to the channel selected in the 3rd digit.

See the **calibration modes** diagram on Page 21 showing a breakdown of 1st, 2nd, and 3rd digits.

## Set Averaging Samples & Averaging Window

Selecting [CAL][22X] enters the Set Averaging Samples and Averaging Windows Mode.

This mode allows you to configure the number of input signal samples to average over, and the size of the averaging window in display counts applied to the channel selected in the 3rd digit.

Selecting [CAL][22X] enters the Set Averaging Samples and Averaging Windows Mode. When in this mode, the [AV\_S] menu allows you to select the number of input signal samples to average over. After setting the number of samples, moving to the [AV\_W] menu allows you to configure the size of the averaging window in displayed counts.

The meter averages the input samples over the selected number of input samples (selected in the [AV\_S] menu). This carries on in a continual process provided the input signal stays within the averaging window (set in the [AV\_W] menu). If the sample moves out of the averaging window, the meter responds quickly to the change by displaying the non-averaged signal value. When the signal stabilizes, a new averaging window is established and averaging resumes.

You can program the number of samples you want to average the input signal over from 1 to 255 samples. The averaging window can be set to between 1 and 65535 counts.

See the **calibration modes** diagram on Page 21 showing a breakdown of 1st, 2nd, and 3rd digits.


See *Input Signal Sampling Showing Averaging Window* diagram opposite.

## Example Procedure

The example procedure on Page 24 shows how to configure channel 1 (CH1) with an averaging sample rate of 10 counts and an averaging window of 1000 counts.

## Totalizer Settings

Selecting [CAL][23X] enters the Totalizer Settings Mode.



Input Signal Sampling Showing Averaging Window

This mode allows you to configure the settings for the totalizer selected in the 3rd digit. An input value of 10000 counts is applied to a selectable time period to produce the required total value.

The cutoff is a programmable limit below which the input is not totalized.

See the **calibration modes** diagram on Page 21 showing a breakdown of 1st, 2nd, and 3rd digits.

Also see the *Totalizing and Batching Supplement (NZ208)* for further details on K factor and totalizer cutoff parameters. (See page 3 for more information).

## Setup 32-point Linearization Tables

Selecting [CAL][24X] enters the Setup 32-point Linearization Tables Mode.

This mode allows you to set up the linearization table or tables using the manual or auto setup modes. The table or tables can then be selected to linearize the signals on channels 1 to 4.

See **Linearization Table Notes** on Page 36 for a description of memory related issues with linearization.

See the **calibration modes** diagram on Page 21 showing a breakdown of 1st, 2nd, and 3rd digits.

Also see the *Linearizing Supplement (NZ207)* for further details on linearization table setup and use. (See page 3 for more information).

## Scale Analog Output

Selecting [CAL][25X] enters the Scale Analog Output Mode.

This mode allows you to calibrate and scale the analog output signal. Before calibrating the analog output in the calibration mode, the data source for the analog output must be configured in Code 1.

See the **calibration modes** diagram on Page 21 showing a breakdown of 1st, 2nd, and 3rd digits.

Also see the *Analog Output Module Supplement (NZ200)* for further details on the analog output module. (See page 3 for more information).

Also see *Configure Data Source Procedure* on Page 27 for an example of setting the analog output data source.

## Calibration Mode Procedures Supplement

The *Advanced Calibration and On Demand Mode Procedures Supplement (NZ203)* describes in detail all Tiger 320 Series meter related calibration procedures configured in the calibration mode.

## Two-point Calibration

Two-point calibration is the most commonly used method of calibrating Tiger 320 Series meters when a low and high input source is available.

### Example Calibration Procedure

Calibrate channel 1 (CH1) using the two-point calibration method. The calibration mode display is set to [111].



The low input source is applied to the meter when setting the zero value.



The high input source is applied to the meter when setting the span value.



### 2-POINT CALIBRATION



## Input Signal Filtering and Averaging



Input signal filtering and averaging is configured in the calibration mode. Programmable averaging allows you to program the number of samples you want to average the input signal over (from 1 to 255 samples).

A programmable averaging window provides a quick response time to large input signal changes. The averaging window can be set to between 1 and 65535 counts.

### Example Procedure:

Select an averaging sampling rate of 10 samples and an averaging window of 1000 counts for Channel 1 by setting [CAL] to [221].


See **Advanced Calibration & On Demand Mode Supplement (NZ203)** for further calibration procedures. (See page 3 for more information).





## CODE 1 – Display Configuration Modes

All meter display modes, except the display brightness mode, are configured in Code 1 (See diagram below). See Code 1 diagram on Page 26 for a breakdown of first, second, and third digit settings.



### Setpoint Annunciators Mode (not available on DI-60X)

The setpoint annunciators mode is configured by changing the first digit in Code 1. The setpoint annunciators can be configured to operate as follows:

- On when the setpoint activates.
- All annunciators are permanently on and each one only goes off when its setpoint activates.
- All annunciators are always off (See Note 1 on Code 1 diagram on Page 26).
- Setpoint 1 annunciator comes **on** indicating a **rising signal**. Setpoint 2 annunciator comes **on** indicating a **falling signal**.

The example procedure on Page 30 shows how to select the setpoint annunciators to come ON when the setpoints are OFF (not active).

### Update Display at Selected Sample Rate

The meter's default display update rate is 0.5 seconds and is set in the second digit of Code 1 as [X0X].

The display can be configured to update at the input signal sample rate selected in Code 2.

The example procedure on Page 30 shows how to configure the display to update at typically 10 samples per second by setting Code 1 to [X2X].

For these settings to take effect, the analog sample rate must be set at [2XX] in Code 2. See *Code 2 – Channel 1 Measurement Task and Sampling Rate* on Page 31 for an example.

### Manual Loader Mode

The meter can be configured to function exclusively as a manual loader by setting Code 1 to [X1X].

See *Analog Output Module Supplement* for full details on manual loader mode functions.

### Display Functions Mode

The display functions mode in Code 1 allows you to configure:

- The data source for the primary display.
- The format of the display with last digit rounding, type of display units, and decimal point placement.
- A text character for the last digit.

The display functions mode is configured by changing the second and third digits in Code 1:

- Selecting [X5X] enters the **Data Source** sub-menu.
- Selecting [X6X] enters the **Display Format** sub-menu.
- Selecting [X7X] enters the **Last Digit Text Character** sub-menu.

#### Data Source – Second Digit [X5X]

The data source for the primary display is configured by selecting **5** in the second digit and the **0** in the third digit.

Note:

[XX1] Second Display and [XX2] Third Display only apply to DI-503 meters with three displays.

The second digit in Code 1 can also be used to configure the data source for the remaining functions in the third digit:

- [X53] = Peak and Valley.
- [X54] = Analog Output 1.
- [X55] = Analog Output 2.
- [X56] = Totalizer 1.
- [X57] = Totalizer 2.

Selecting **5** in the second digit enters a sub-menu and allows you to select the data from one of a number of meter registers as the data source for the displays or functions selected in the third digit.

The example procedure on Page 27 shows how to select the data source for the **primary** display. The three digits are set to [X50].

#### Display Format – Second Digit [X6X]

Selecting **6** in the second digit enters the Display Format sub-menu where the following display format settings can all be configured:

- Last digit rounding.
- Display units (Decimal, octal, or optional 12 or 24-hour clock).
- Decimal point placement.

The example procedure on Page 28 shows how to configure the three display format modes for the third digit selection.

#### Text Character – Second Digit [X7X]

Selecting **7** in the second digit allows you to select one of 54 characters and apply it to the last digit when the meter is in the operational display.


For example, if the meter was measuring a temperature, the display could be configured to display the reading with a C or an F in the last digit for °C or °F.

The example procedure on Page 29 shows how to configure the last digit text character as “C” for centigrade (°C) for the third digit selection.


Note:

After setting any or all the above three modes [X5X], [X6X], [X7X], the Code 1 display must set back to [X0X] to leave Code 1 and carry on programming.


# [CodE\_1] - Display Configuration continued



## Select Data Source




## Display Format Mode



*Note 3:* These functions are only available on selected input modules.

*Note 4:* If Code 1's display functions mode has been entered (second digit set to 6), the display will cycle between Code 1 and the display functions mode each time the PROGRAM button is pressed. To leave the cycle, the Code 1 digits must be reset to [000]. This takes you into Code 2.

## Select Last Digit Text Character



## Configure Data Source Procedure

The following example procedure describes how to select the source of the data to be displayed for the third digit selection.

### Example Procedure:

Configure the Primary Display with the display [diSP] as the data source by setting Code 1 to [X50]. See diagram below for data source selection options.





#### Programming Tip

To enter the Main Programming Mode press the [P] and [↑] buttons at the same time. To exit and return to the operational display, press the [P] and [↓] buttons again at the same time.

At the end of any procedure (Step 8 in this procedure) the [P] must be pressed before the [P] and [↓] buttons are pressed, otherwise the meter returns to the operational display without saving the new settings.

#### Select Data Source



Note:  
Options 1 and 2 listed for the 3rd digit in Step 3 above are only for use with meters that have more than one display. With bargraph meters the PRIMARY display is the digital display, and the SECONDARY display is the bargraph display.

## Configure Display Format Mode Procedure

The following example procedure describes how to configure the display format mode for the third digit selection and covers:

- Last Digit Rounding.
- Display Units.
- Decimal Point Placement.

### Example Procedure:

Configure the display format mode for channel 1 with rounding by 2's, decimal display units, and the decimal point placed between display digits 4 and 5 by setting Code 1 to [X61].

### Display Format Mode


P d i s p 000 Program the three digits to the required display format mode

FIRST DIGIT
LAST DIGIT ROUNDING
0 No rounding
1 Rounding by 2's
2 Rounding by 5's
3 Rounding by 10's

SECOND DIGIT
DISPLAY UNITS
0 Decimal
1 Hours:Minutes:Seconds
2 12-hour clock mode (12:30 am is displayed as 12:30A. 12:30 pm is displayed as 12:30P)
3 Days:Hours:Minutes
4 -
5 -
6 -
7 Octal

THIRD DIGIT
DECIMAL POINT PLACEMENT
0 No decimal point
1 -
2 -
3 X.XXXXX
4 X.XXXX
5 X.XX
6 X.X
7 Decimal Point set from the rear (X.XXXXX to XXXXXX). See Note 3. Also See Note 4

Note:  
Selecting 1, 2, or 3 in the second digit of the Display Format Mode configures the display of the selected channel (see Step 4) as a clock.






## Configure Last Digit Text Character Procedure

The following example procedure describes how to select the last digit text character.

### Example Procedure:

Configure the Channel 1 with C as its last digit text character (for °C) by setting Code 1 to [X71]. See diagram opposite.




## Configure Update at Sample Rate Procedure

The following example procedure describes how to configure the display to update at the sample rate selected in Code 2.

### Example Procedure:

Update the display at the sample rate selected in Code 2 by setting Code 1 to [X2X].



# [CodE\_2] - Channel 1 Measurement Task & Sampling Rate

The Tiger 320 Series DI-60 meter can be configured to measure almost any input signal. The measurement task and sampling rate for Channel 1 (CH1) is configured in the three digits of Code 2. The diagram below lists the available configuration selections in Code 2.

## Example Procedure:






Configure CH1 for a voltage input with 10 samples/second (60 Hz rejection) sampling rate and output rate of 0.1 secs by setting Code 2 to [000].

FIRST DIGIT	SECOND DIGIT	THIRD DIGIT
<b>CODE 2 – CHANNEL 1 MEASUREMENT TASK AND SAMPLING RATE</b>		
<b>ANALOG SAMPLE RATE</b>		<b>MEASUREMENT TASK</b>
<b>0</b> Sample Rate: Typically 10 samples/second (60 Hz rejection) Output Rate: 0.1 seconds See Example	<b>0</b> Voltage, Current	<b>FOR VOLTAGE</b> <b>0</b> No function 1 Peak detector 2 Pressure with Auto-cal
<b>1</b> Sample Rate: Typically 10 samples/second (50 Hz rejection) Output Rate: 0.1 seconds See Example	<b>1</b> TC (third digit selects type of TC)	<b>FOR THERMOCOUPLE</b> <b>0</b> Type J 1 Type K 2 Type R 3 Type S 4 Type T 5 Type B 6 Type N 7 Select User Defined Table 1 set-up in Code 3 [X7X]. To invoke Table 1, reset Code 3 to [00X]
<b>2</b> Sample Rate: Typically 10 samples/second (60 Hz rejection) Output Rate: 10 milliseconds See Example	<b>2</b> RTD 3-wire (third digit selects type of RTD)	<b>FOR RTD TYPE (2-, 3-, 4- WIRE)</b> <b>0</b> Resistance 1 RTD 385 2 RTD 392 3 RTD 120 4 Cn 10
<b>3</b> Sample Rate: Typically 10 samples/second (50 Hz rejection) Output Rate: 10 milliseconds See Example	<b>3</b> RTD 2- or 4-wire (third digit selects type of RTD)	<b>FREQUENCY RANGE</b> <b>0</b> 99.999 Hz range from 0.010 Hz 1 99.999 Hz range from 2.000 Hz 2 999.99 Hz range from 0.01 Hz 3 999.99 Hz range from 2.00 Hz 4 9999.9 Hz range from 0.1 Hz 5 9999.9 kHz range from 2.0 Hz 6 99 kHz range from 1 Hz (1 s gate) 7 655.35 kHz range from 10 Hz (0.1 s gate)
<i>Note:</i> Output Rate refers to setpoint and macro outputs, and input rates from smart input modules.	<b>4</b> Frequency	<b>PERIOD MEASUREMENT</b> <b>0</b> 99.999 s 1 9.9999 s 2 999.99 ms 3 99.999 ms
<i>Note:</i> All above sample rates are quoted for single channel operation. Where more than one channel is available, sample rates are divided by the number of active channels. See Example.	<b>5</b> Period	<b>COUNTER/RESIDENT TIMER/CLOCK</b> <b>0</b> Counter input with 16 bit Pre-scaler 1 Setting of 16-bit Pre-scaler 2 Pre-scaler and Debounced counter 3 Up/Down Counter with Pre-scaler 4 Stop watch HRS:MIN:SEC 5 Stop watch DAYS:HRS:MIN 6 External 24-hour clock 7 Internal 24-hour clock
	<b>6</b> Counter	<b>SMART INPUT MODULE</b> <b>0</b> Output Register 1 1 Output Register 2 2 Output Register 3 3 Output Register 4 4 Output Register 5 5 Output Register 6 6 Output Register 7 7 Smart Input Module Setup.
	<b>7</b> Smart Input Module	

**Example: 10 Samples/Second**  
 1 Channel = 10 samples/second  
 2 Channels = 5 samples/second  
 3 Channels = 3.33 samples/second  
 4 Channels = 2.5 samples/second

X61 Sets Prescaler	
1 =	0.1 second
10 =	1 second
600 =	1 minute
36000 =	1 Hour***

\*\*\*Note: For the 1 hour setting, the scale factor for CH1 must be set to 0.1 in the calibration mode setting [111].  
 Use  $\uparrow$   $\downarrow$  buttons to set prescale values



# [Code\_3] - Channel 1 Post Processing & Serial Mode Functions

Post processing functions refer to functions that occur to the input after it has been configured and scaled.


Post processing for Channel 1 (CH1) is configured in the first digit of Code 3. The diagram below lists the available post processing configuration selections in Code 3 (First digit only).

FIRST DIGIT	SECOND DIGIT	THIRD DIGIT
<b>CODE 3 – CHANNEL 1 FUNCTIONS (POST PROCESSING &amp; SERIAL MODE)</b>		
<b>CH1 POST PROCESSING</b>	<b>32-POINT LINEARIZATION FOR CHANNEL 1</b>	<b>SERIAL MODE</b>
0 Direct Display of Input (no processing) 1 Square Root of Channel 1 2 Inverse of Channel 1 3 -	0 No Linearization on CH1 1 32-point Linearization on CH1 using Table 1 2 32-point Linearization on CH1 using Table 2. See Note 5 3 32-point Linearization on CH1 using Table 3. See Note 5 4 32-point Linearization on CH1 using Table 4. See Note 5 5 125-point Linearization on CH1 (Tables 1 to 4 cascaded). See Note 5 6 32-point Linearization on CH1 (Tables 1 to 4 selected from the rear pins of selected input modules). See Note 5 7 - Note: All linearization tables are set up in the Calibration Mode [24X].	0 ASCII Mode 1 Modbus Mode 2 Master mode (used to customize print mode protocols via macro) 3 Print Mode 4 Ethernet Mode. See Note 6 5 DeviceNet Mode (requires DeviceNet hardware module). See Note 6

Note 5:  
If only 4 kB memory installed, functions 2 to 6 are not available in:

- Code 3 second digit.
- Code 4 third digit.
- Code 7 second digit.

Note 6:  
These functions are not available on all models and in some cases require additional hardware.



## Example Procedure:

Configure the meter to apply square root to the CH1 signal by setting Code 3 to [100].

### Print Mode – Data Download Direct to Serial Printer

Print mode data logging is a simple method of logging data using the meter's print mode. The data can be downloaded directly to a serial printer from the meter.

The print mode uses the meter's serial communications port to connect to a remote serial printer. The data can be printed with or without a Day: Month: Year or Hours: Minutes: Seconds time stamp.

Time stamp settings are configured in Code 8.

### Print Mode – Data Download Direct to PC

The print mode can also be used to download data to a PC where it is logged in a Windows Terminal program.

The print mode uses the meter's serial communications port to connect to the PC. The data can be logged with or without a Day: Month: Year or Hours: Minutes: Seconds time stamp.

Time stamp settings are configured in Code 8.



# [CodE\_4] - Channel 2 Measurement Task & Sampling Rate

Code 4 is a single code that combines all the configuration and post processing functions available for Channel 2.

When a **dual input** signal conditioner is installed, the second input signal is processed and displayed on CH2.

Measurement task and 32-point linearization for CH2 is configured in the first and second digits of Code 4. The diagram opposite lists the available configuration selections in Code 4.

### Example Procedure:

Configure CH2 for a voltage input with the processed input signal inverted with no linearization by setting Code 4 to [030].


**See I-Series Input Modules Guide (Z87) for procedures to set up a dual input module.**

FIRST DIGIT	SECOND DIGIT	THIRD DIGIT
<b>CODE 4 – CHANNEL 2 MEASUREMENT TASK AND 32-POINT LINEARIZATION</b>		
<b>MEASUREMENT TASK</b>	<b>FOR VOLTAGE &amp; CURRENT</b>	<b>32-POINT LINEARIZATION FOR CH2</b>
<b>0</b> Voltage, Current 1 TC (type as per 2nd digit) 2 RTD (type as per 2nd digit) 3 Second Digital Input Channel (type as per 2nd digit)	<b>0</b> Channel 2 Disabled 1 Direct (no post processing) 2 Square Root of Channel 2 3 Inverse of Channel 2 4 Output Register 1 (smart module) 5 Output Register 2 (smart module) 6 Output Register 3 (smart module) 7 Output Register 4 (smart module)	<b>0</b> No user defined Linearization on CH2 1 32-point Linearization on CH2 using Table 1 2 32-point Linearization on CH2 using Table 2. See Note 5 3 32-point Linearization on CH2 using Table 3. See Note 5 4 32-point Linearization on CH2 using Table 4. See Note 5 5 125-point Linearization on CH2 (Tables 1 to 4 cascaded). See Note 5 6 – 7 –
	<b>FOR THERMOCOUPLE</b>	
	<b>0</b> Type J 1 Type K 2 Type R 3 Type S 4 Type T 5 Type B 6 Type N 7 Select User Defined Table - Uses linearization Table 1 (32-point). Table 1 must be set up in Code 5 [X7X].	
	<b>FOR RTD TYPE (3-WIRE)</b>	
	<b>0</b> Resistance 1 RTD 385 2 RTD 392 3 RTD 120 4 Cn10	
	<b>DIGITAL INPUT</b>	
	<b>0</b> Frequency - 99.999 Hz range from 0.01 Hz 1 Frequency - 999.99 Hz range from 0.01 Hz 2 Frequency - 99.999 kHz range from 1 Hz (1 s gate) 3 Frequency - 500 kHz range from 10 Hz (0.1 s gate) 4 Period - 9.9999 s (100 µs resolution) 5 Period - 99.999 ms (10 µs resolution) 6 Up/Down Counter with Prescaler 7 Set Prescaler	

**Note 5:**  
 If only 4 kB memory installed, functions 2 to 6 are not available in:

- Code 3 second digit.
- Code 4 third digit.
- Code 7 second digit.

PRE\_S [ ] [ ] [ ]  
 Use ↑ ↓ buttons to set prescale values from 1 to 65535 counts



# [CodE\_5] - Channel 3 Functions

Code 5 is a single code that combines all the configuration and post processing functions available for Channel 3.

When a **triple input** signal conditioner is installed, the third input signal is processed and displayed on CH3.


Post processing and measurement task functions for CH3 are configured in the first, second, and third digits of Code 5. The diagram opposite lists the available configuration selections in Code 5.

FIRST DIGIT	SECOND DIGIT	THIRD DIGIT
<b>CODE 5 - CHANNEL 3 FUNCTIONS</b>		
<b>CH3 POST PROCESSING</b> 0 Direct Display of Input (no processing) 1 Square Root of Channel 3 2 Inverse of Channel 3 3 32-point Linearization of CH3 using Table 3	<b>MEASUREMENT TASK</b> 0 No Function 1 Voltage / current 2 TC (third digit selects type of TC) 3 RTD (third digit selects type of RTD) 4 Real Time Clock & Timer (third digit selects type) 5 - 6 - 7 Smart Input Module (third digit selects register)	<b>FOR THERMOCOUPLE</b> 0 Type J 1 Type K 2 Type R 3 Type S 4 Type T 5 Type B 6 Type N 7 Select User Defined Table 1 set-up in Code 3 [X7X]. To invoke Table 1, reset Code 3 to [00X]
		<b>FOR RTD TYPE (2-, 3-, 4-WIRE)</b> 0 Resistance 1 RTD 385 2 RTD 392 3 RTD 120 4 Cn 10
		<b>FOR REAL-TIME CLOCK &amp; TIMER</b> 0 HRS:MIN:SEC 1 HRS:MIN 2 - 3 - 4 1 Second Count UP Timer 5 1 Second Count DOWN Timer 6 - 7 -
		<b>FOR SMART INPUT MODULE</b> 0 Output Register 1 1 Output Register 2 2 Output Register 3 3 Output Register 4 4 Output Register 5 5 Output Register 6 6 Output Register 7 7 Smart Input Module Register 2 Code Setup

### Example Procedure:

Configure CH3 to display the square root of a voltage input by setting Code 5 to [11X].

See *I-Series Input Modules Guide (Z87)* for procedures to set up a triple input module.



# [CodE\_6] - Channel 4 Functions

Code 6 is a single code that combines all the configuration and post processing functions available for Channel 4.

When a **quad input** signal conditioner is installed, the fourth input signal is processed and displayed on CH4.

Post processing and measurement task functions for CH4 are configured in the first, second, and third digits of Code 6. The diagram opposite lists the available configuration selections in Code 6.

### Example Procedure:


Configure CH4 for a voltage input with the CH4 processed input signal inverted by setting Code 6 to [21X].

**See I-Series Input Modules Guide (Z87) for procedures to set up a quad input module.**


FIRST DIGIT	SECOND DIGIT	THIRD DIGIT	
<b>CODE 6 - CHANNEL 4 FUNCTIONS</b>			
<b>CH4 POST PROCESSING</b>			
0 Direct Display of Input (no processing)	<b>MEASUREMENT TASK</b>		
1 Square Root of Channel 4			
2 Inverse of Channel 4			
3 32-point Linearization of CH4 using Table 4			
		<b>FOR THERMOCOUPLE</b>	
		0 Type J	
		1 Type K	
		2 Type R	
		3 Type S	
		4 Type T	
		5 Type B	
		6 Type N	
		7 Select User Defined Table 1 set-up in Code 3 [X7X]. To invoke Table 1, reset Code 3 to [00X]	
		<b>FOR RTD TYPE (2-, 3-, 4- WIRE)</b>	
		0 Resistance	
		1 RTD 385	
		2 RTD 392	
		3 RTD 120	
		4 Cn 10	
		<b>FOR REAL-TIME CLOCK &amp; TIMER</b>	
		0 HRS:MIN:SEC	
		1 HRS:MIN	
		2 -	
		3 -	
		4 1 Second Count UP Timer	
		5 1 Second Count DOWN Timer	
		6 -	
		7 -	
		<b>FOR SMART INPUT MODULE</b>	
		0 Output Register 1	
		1 Output Register 2	
		2 Output Register 3	
		3 Output Register 4	
		4 Output Register 5	
		5 Output Register 6	
		6 Output Register 7	
		7 Smart Input Module Register 3 Code Setup	

Note:  
For future development.


Step 1





Step 2




Step 3



Step 4



Step 5



# [CodE\_7] - Result Processing

The third digit of Code 7 performs various math functions between channel 1 and channel 2 and stores this data in the result register.

The data in the result register can then be further processed by the selections made in the first and second digits.

FIRST DIGIT	SECOND DIGIT	THIRD DIGIT
<b>CODE 7 – RESULT PROCESSING</b>		
<b>RESULT PROCESSING</b>	<b>32-POINT LINEARIZATION FOR RESULT</b>	<b>MATHS FUNCTIONS FOR RESULT</b>
<b>0</b> Direct Display of Result as per processing performed in 2nd or 3rd digit 1 Square Root of Result 2 Inverse of Result 3 -	<b>0</b> No Linearization on Result 1 32-point Linearization on Result using Table 1. 2 32-point Linearization on Result using Table 2. See Note 5 3 32-point Linearization on Result using Table 3. See Note 5 4 32-point Linearization on Result using Table 4. See Note 5 5 125-point Linearization on Result (Tables 1 to 4 cascaded). See Note 5 6 32-point Linearization on Result (Tables 1 to 4 selected from the rear of the meter). See Note 5 7 -	<b>0</b> Result Register not Updated 1 pH Meter (CH1 = Tbuff, CH2 = pH) 2 Result = CH1, Setpoint 2 = CH2 3 Result = CH1 + CH2 4 Result = CH1 - CH2 5 Result = (CH1 x 20 000)/CH2 6 Result = CH1 x CH2/10 000 7 Result = CH1

### Example Procedure:

Configure Code 7 to add the input of CH1 and CH2 and directly display the result by setting Code 7 to [003].

**See I-Series Input Modules Guide (Z87) for procedures to set up a dual, triple, or quad input module.**

### Linearization Table Notes

A base meter with 4 kB memory installed has a single 32-point programmable linearization table available.

For four 32-point programmable linearization tables to be available, the meter requires at least 32 kB of memory to be installed.

#### Meters with 4 kB Memory

In base meters with 4 kB memory, set up Table 1 in the Calibration Mode to [24X]. This means that Table 1 is available to be applied to:


- CH1 – Selected in Code 3.
- CH2 – Selected in Code 4.
- CH3 – Selected in Code 5.
- CH4 – Selected in Code 6.

#### Meters with 32 kB Memory


In base meters with 32 kB or more memory, each of the four tables (Tables 1 to 4) are set up in [24X] of the Calibration Mode by selecting the appropriate table number. This means that the four tables are available for the four channels as follows:

- CH1 – All four tables selected in Code 3.
- CH2 – All four tables selected in Code 4.
- CH3 – Table 3 selected in Code 5.
- CH4 – Table 4 selected in Code 6.

Step 1




Step 2




Step 3

- 1st Digit = 0 Selects direct display of result
- 2nd Digit = 0 Selects no linearization on result
- 3rd Digit = 3 Selects result = CH1+CH2



Step 4

Step 5



## [CodE\_8] - Data Logging & Print Mode

Up to 4000 samples can be logged within the meter in the cyclic or linear FIFO mode and saved for later downloading to a PC, using Windows HyperTerminal, or directly to a serial printer.

Data logging can be triggered (activated) from a setpoint, the program button, or from an external switch. See the third digit in the diagram below.

Data from up to four selectable registers can be logged with one of the following printer or spreadsheet style time and date stamps. All time and date stamps are generated from an optional real-time clock (see the second digit in the diagram below):

- No time stamp.
- Month - Day - Year. Hours:Minutes:Seconds.
- Day - Month - Year. Hours:Minutes:Seconds.
- Hours:Minutes:Seconds.

Printer style time and date stamps have a carriage return and line feed. Spreadsheet style time and date stamps are continuous on a single line.

**See *Serial Communications Module Supplement (NZ202)* for full details on the Data Logging and Print Mode Options.**

FIRST DIGIT	SECOND DIGIT	THIRD DIGIT
<b>CODE 8 – DATA LOGGING AND PRINT MODE OPTIONS</b>		
<b>DATA LOG BUFFER TYPE</b>	<b>TIME STAMP OPTIONS</b>	<b>TRIGGER FUNCTIONS</b>
<b>0 No Data Logging</b> 1 Cyclic Buffer 2 Linear FIFO Buffer. <i>See Note 6</i> 3 Reset Linear FIFO Buffer. <i>See Note</i>  <i>Note:</i> <i>First digit codes are not available in bargraph versions.</i>	<b>0 Printer Format – No time stamp with print/log</b> 1 Printer Format – Time stamp format 1 [Mth-Day-Yr Hrs:Min:Sec] (with <CR><LF>) 2 Printer Format – Time stamp format 2 [Day-Mth-Yr Hrs:Min:Sec] (with <CR><LF>) 3 Printer Format – Time stamp format 3 [Hrs:Min:Sec] (with <CR><LF>) 4 Spreadsheet Format – No time stamp with print/log 5 Spreadsheet Format – Time stamp format 1 [Mth-Day-Yr Hrs:Min:Sec] 6 Spreadsheet Format – Time stamp format 2 [Day-Mth-Yr Hrs:Min:Sec] 7 Spreadsheet Format – Time stamp format 3 [Hrs:Min:Sec]	<b>0 No trigger</b> 1 Trigger on Demand from PROGRAM Button 2 Trigger on Demand from F1 Button 3 Trigger on Demand from F2 Button 4 Trigger on Demand from HOLD Pin 5 Trigger on Demand from LOCK Pin 6 - 7 -  <i>Note:</i> <i>Log and/or print will only trigger if enabled.</i>
<b>ALL ABOVE ARE REAL-TIME CLOCK OPTIONS</b>		

*Note 6:*  
*For future development.*

## [CodE\_9] - Functions for Digital Input Pins

The TEST, HOLD, and LOCK pins are located at the rear of the meter to accommodate external switched digital inputs. When switched to the COMMON pin, they can be programmed in Code 9 to perform remote resetting functions to add to the functionality of the meter.

CODE 9 – FUNCTIONS FOR DIGITAL INPUT PINS		
DISPLAY TEST PIN	HOLD PIN	LOCK PIN
<b>0 Display test only</b> 1 Reset Counter Channel 1 and Subtotal at Power-up 2 Reset Counters Channel 1, 2, 3, 4, Total 1, and Total 2 at Power-up 3 Reset Total 1, and Total 2 at Power-up	<b>0 Display Hold</b> 1 Reset Channel 1 2 Reset Total 1 and Total 2 3 Reset Total 2 4 Reset Peak, Valley 5 Reset Tare 6 Set Tare 7 Unlatch (de-energize) all Setpoints	<b>0 Key Lock</b> 1 Reset Channel 1 2 Reset Channel 2 3 Reset Channel 3 4 Reset Channel 4 5 Reset Tare 6 Reset Total 7 Unlatch (de-energize) all Setpoints

# Setpoint Programming Mode

All setpoint activation and control settings are selected and configured using the front panel buttons in the **setpoint programming mode**. Or, software configured via the **meter configuration utility program** if the meter is connected to a PC through the serial port. The meter has six software driven setpoints, independently configured to operate within the total span range of the meter and the selected input module.


## Relay Output Modules

Five standard relay output module options provide a selection of 20 relay configuration options for DI-50 meters.


Three electromechanical relay output modules support a combination of 5 A Form A and 10 A Form C relays providing 12 configuration options. A solid state relay (SSR) output module supports 400 V, 210 mA DC SSRs and another SSR output module supports 400 V, 140 mA AC / DC SSRs providing a further eight configuration options.

A 22 opto-isolated I/O plug-in module can support six inputs and up to 16 outputs. The standard plug-in module has six inputs and six outputs that can be extended to 16 outputs with a 10 output add-on board.

### 320 Series Relay Output Module Options



### Optional Opto-isolated 22 I/O Plug-in Module



## Setpoint Programming Mode

See the *Setpoint Programming Mode Logic Diagram* opposite.

The setpoint programming mode is entered by pressing the meter's **P** and **↓** buttons at the same time.

### Setpoint Activation Values


Each setpoint activation value is individually programmed. Setpoint activation values can be set within the total span range of the meter and the selected input module.

### Setpoint and Relay Control Settings


See the *Setpoint and Relay Control Settings diagram* on Pages 42 and 43.

The control settings provide access to the following setpoint and relay functions for configuration using the meter's 1st, 2nd, and 3rd digits:

- **1st Digit** – Relay Energize Functions.
- **2nd Digit** – Setpoint Activation Source.
- **3rd Digit** – Setpoint Delay, Timer, and Reset and Trigger Functions.




Setpoint Programming Mode Logic Diagram




## Relay Energize Functions

All setpoints activate at the setpoint value. All relays/setpoints are programmable to energize above or below the setpoint value.



## Setpoint Activation Source

Setpoints activate from any input channel, selected meter register, or external switched inputs (digital input pins).



## Setpoint Latching

Setpoints can be programmed in relay latching modes.

## SP TRIGGER OPERATES ON:

- MAKE EDGE
- BREAK EDGE
- MAKE & BREAK EDGE
- EVERY SAMPLE PERIOD

## SP RESET SELECTED REGISTER

## SP TRIGGER PRINT

## SP TRIGGER LOG DATA

## Setpoint Reset & Trigger

Setpoints can be programmed to reset selected registers, or be manually reset. They can also trigger a data print or a data log.



## Setpoint Tracking


Setpoint tracking can be applied to setpoints configured in the hysteresis, deviation, or PID modes.



## Display Flashing

Display flashing can be applied to setpoints configured in the hysteresis or deviation modes.

Each setpoint can be programmed to make the display flash on and off while the setpoint is active, and keep it flashing until the setpoint de-activates.




## Real-time Clock Option

Any setpoint can be programmed to operate from the real-time clock option.




## Data Logging

Any setpoint can be programmed to log data within the meter (up to 4000 samples).



## Data Printing to Serial Printer

Any setpoint can be programmed to send data directly to a serial printer.



## Data Printing to PC

Any setpoint can be programmed to send data directly to a connected PC.



Hysteresis



Deviation

## Hysteresis or Deviation

Each relay can operate in a hysteresis or deviation mode.



## PID Control Settings

The PID (proportional, integral, derivative) control function provides exceptional control stability during control process applica-


tions. PID control is available from the following outputs:

- Setpoint / relay output.
- Analog output.
- Relay and analog output at the same time.

PID control from the setpoint / relay output is available from SP1 and SP2 only.


There are two PID control outputs available via the analog output:

- PID1 – stored in register 50.
- PID2 – stored in register 51.



## Timer Modes

Each setpoint can be programmed to operate the relay in one of the following seven resident timer modes:



### Normal Mode Timer

Single actuation, delay-on-make (DOM) and delay-on-break (DOB).

### Normally OFF/Pulsed ON Timers

**Repeat ON Mode Timer** – multiple actuation, programmable off- and on-time.

**Pulse ON Mode Timer** – single actuation, programmable DOM and maximum on-time.

**1-Shot ON Mode Timer** – single actuation, programmable DOM and minimum on-time.

### Normally ON/Pulsed OFF Timers

**Repeat OFF Mode Timer** – multiple actuation, programmable off- and on-time.


**Pulse OFF Mode Timer** – single actuation, programmable DOB and maximum off-time.

**1-Shot OFF Mode Timer** – single actuation, programmable DOB and minimum off-time.

## Hysteresis or Deviation

Each setpoint can be individually programmed to energize the relay in the hysteresis or deviation mode, with or without initial startup inhibit.

**Hysteresis** (deadband) is the programmable band above and below the setpoint value that determines when and for how long the relay is energized or de-energized. The setpoint can be programmed to energize the relay above or below the setpoint value.



The hysteresis setting can be any value between 0 and 65535 counts. The number of counts selected act both positively and negatively on the setpoint, forming a hysteresis band around the setpoint.


For example, if the setpoint setting is 500 counts and the hysteresis setting is 10 counts, the hysteresis band around the setpoint setting is 20 counts, starting at 490 counts and ending at 510 counts.

*Note:*

*If hysteresis is set with ZERO counts, the relay energizes AT or ABOVE the setpoint value.*

## Setpoint Programming Mode continued

**Deviation** (passband) is the programmable band around the setpoint in which the setpoint can be programmed to energize the relay inside or outside the deviation band.




The deviation setting can be any value between 1 and 65535 counts. The number of counts selected act both positively and negatively on the setpoint, forming a deviation band around the setpoint.

For example, if the setpoint setting is 1000 counts and the deviation setting is 35 counts, the deviation band around the setpoint setting is 70 counts starting at 965 counts and ending at 1035 counts.

### Initial Start-up Inhibit.

On power-on, start-up inhibit prevents the relay from energizing on the first setpoint activation cycle. Depending on how the meter has been programmed, initial start-up inhibit either functions during a falling input signal, or during a rising input signal.




### Relay Time Control Modes

The following time control mode settings can cover almost every relay timer application.

All setpoints can be individually programmed to operate a relay in one of the following time control modes above or below the setpoint value.

#### Normal Mode

This mode individually programs a relay's setpoint with delay-on-make (DOM) and delay-on-break (DOB) settings.




#### Normally OFF / Pulsed ON Modes

These are delay modes where the relay is normally off and pulses on when the setpoint activates.


##### Repeat ON Mode

Multiple actuation, programmable on and off time settings.




##### Pulse ON mode (Programmable ON-time)

Single actuation, programmable DOM and on time settings.



##### 1-Shot ON mode (Programmable Minimum ON-time)

Single actuation, programmable DOM and minimum on time settings.




#### Normally ON / Pulsed OFF Modes

These are delay modes where the relay is normally on and pulses off when the setpoint activates.


##### 1-Shot OFF mode (Programmable Minimum OFF-time)

Single actuation, programmable minimum off time and DOB settings.




### Pulse OFF mode (Programmable OFF-time)

Single actuation, programmable off time and DOB.



### Repeat OFF Mode

Multiple actuation, programmable off and on time settings.



Each setpoint can be individually configured for basic to advanced operations in the following three levels. Each operational level is designed to provide only the required relevant setpoint and relay functions.

The modes at Level 2 and Level 3 can be set to OFF for each individual setpoint, ensuring that no other functions are programmed to influence the setup.

## Level 1 Setpoint & Relay Basic Mode

This is an easily programmable mode for users who require the following basic setpoint and relay functions:

### First Digit – Relay Energize Functions

Relays programmed to energize above or below the setpoint value.

### Second Digit – SP Activation Source

Setpoints programmed to activate from selectable meter registers or one of six external switched inputs.

### Third Digit – Setpoint Latching

Relays programmed with latching and manual reset options.

## Level 2 Setpoint & Relay Intermediate Mode

Level 2 uses all Level 1 functions and is further extended by the following programmable modes. The functionality of the relay energize functions are extended by allowing the relays to be programmed with or without initial start-up inhibit.

### Hysteresis, Deviation & PID Mode

This mode adds extra functionality to the basic mode by providing programmable hysteresis or deviation settings for all setpoints, or PID control from setpoints SP1 and SP2.

### Timer Modes

These modes add even more functionality to the basic and intermediate mode by providing each setpoint with a choice of one of seven resident programmable timers.

## Level 3 Setpoint & Relay Advanced Mode

Level 3 uses all Level 1 and Level 2 functions combined with reset and trigger functions to provide an extremely powerful advanced mode.

Level 3 enables you to program all setpoints individually for operations normally requiring sophisticated controllers.




## Level 1 - Basic Mode - Programming Procedures

**Example Procedure:**

The following procedure describes how to program setpoint 1 (SP1) for the following **Level 1** setpoint and relay functions:

- SP1 to activate from Channel 1 (CH1).
- Relay to energize above SP1 value.
- Relay to latch with manual relay reset.

**See *Setpoints and Relays Supplement (NZ201)* for procedures to program all setpoint and relay operational levels (Level 1 to Level 3). (See page 3 for more information).**




**Programming tip**  
All required setpoint activation values (SP1 to SP6) can be adjusted before programming setpoint and relay control function settings. See *Setpoint Programming Mode Logic Diagram* on Page 42.


# Setpoint Programming Mode continued

## Setpoint & Relay Control Settings Diagram

The diagram below and continued on Page 43 shows the first, second, and third digit control settings for the setpoints and relays.



### Set Up Hysteresis, Deviation & PID Mode Settings



# Setpoint Programming Mode continued

## Set Up Timer Delay Settings



### Programming Tip

If you do not require any of the functions in this mode, ensure it is set to:

Reset SPC\_X to XX0

Third digit set to [XX6]

Normal Mode

Delay-on-make (doM) time 0.0 to 6553.5 secs      Delay-on-break (dob) time 0.0 to 6553.5 secs

1-Shot ON Mode

doM 0.0 to 6553.5 secs      Minimum on-time (M\_on) 0.0 to 6553.5 secs

Pulse ON Mode

Resolution setting applies to SP1/SP2 ONLY       doM 0.0/0.001 to 6553.5/65.535 secs      Maximum on-time (on\_t) 0.0/0.001 to 6553.5/65.535 secs

Repeat ON Mode

Resolution setting applies to SP1/SP2 ONLY       Off-time (oFF\_t) 0.0/0.001 to 6553.5/65.535 secs      On-time (on\_t) 0.0/0.001 to 6553.5/65.535 secs

1-Shot OFF Mode

Minimum off-time (M\_of) 0.0 to 6553.5 secs      dob 0.0 to 6553.5 secs

Pulse OFF Mode

Resolution setting applies to SP1/SP2 ONLY       Maximum off-time (oFF\_t) 0.0/0.001 to 6553.5/65.535 secs      dob 0.0/0.001 to 6553.5/65.535 secs

Repeat OFF Mode

Resolution setting applies to SP1/SP2 ONLY       Off-time (oFF\_t) 0.0/0.001 to 6553.5/65.535 secs      On-time (on\_t) 0.0/0.001 to 6553.5/65.535 secs

## Set Up Register Reset and Setpoint Trigger Functions

Third digit set to [XX7]

Selecting [oFF] in the Destination Register Reset Setup takes you to Setpoint Print Trigger Setup

Select Reset Destination Register      Select Print Triggered by Setpoint      Select Log Triggered by Setpoint      Reset SPC\_X to [XX0]

[244 to 1]     

Use the  and  buttons to cycle through the options

Select Reset Mode      Select Reset Constant

Selecting any destination register takes you to Mode Reset

Select [rEG] to access the source parameter to select the number of the Modbus register in the meter to be copied to the reset destination register

     Use the   buttons to cycle through the Registers Menu and Registers (1 to 244) to select which register's contents are to be copied into the destination register by a setpoint (also see page 44).     



### Programming Tip

If you do not require any of the functions in this mode, ensure it is set to:

# Registers That Can Be Selected By Front Panel Push Button Programming

A Tiger 320 Series meter has 6,144 registers which are provided for use by the operating system and the powerful Custom Macro Programming system (see page 11).

## 40 Manually Selectable Registers

Using the front panel buttons, there are 40 registers that may be selected for use within the following functions:

- **[CodE\_1] - Display Configuration [X50]**. Selection of a register as the data source for displays, peak and valley, totalizers and analog outputs. (See pages 26 & 27)
- **Setpoint Control Settings [X1X]**. Selection of a register as the data source for a setpoint. (See Page 42)
- **Setpoint Control Settings [XX7]**. Selection of a destination register that is to be reset by a setpoint with the contents of a selected source register. (See Page 43)
- **Setpoint Control Settings [XX7]**. Select which register's contents are to be copied into the destination register by a setpoint. (See Page 43)

The 40 registers that can be selected as a data source, a reset source or a reset destination for the functions above are shown in the table on the right.


The table shows, in seven columns, the functions where these registers can be used.

Where a register is more likely to be used in a particular function, a closed circle ● is shown in the column. For those functions where a register is less likely to be used, an open circle ○ is shown.

No register number is shown for the first 11 functions, because these 11 functions are identified in the display menu for direct selection by their code names.

When cycling through the Registers Menu and then Registers 1 to 244, the numerical Register Set will increment through each decade in turn, from 1 to 0, while the button is held down. When [200] is reached, [oFF] or [tArE] will be displayed. To select a specific number set, the button should be released and pressed again each time the left most decade displays the desired number for that decade.


To quickly exit the numerical 1 to 244 Register Set, hold the [↓] button down while cycling through the decades, and release it when [oFF] or [tArE] appears.



Register Functions	Register Numbers	Data Source for Displays	Data Source for Peak & Valley	Data Source for Analog Outputs 1 & 2	Data Source for Totalizers 1 & 2	Data Source for Setpoints	Reset Source	Reset Dest.
Display [diSP]	-		●	●	●	●		
Result [rESL]	-	●	●	●	●	●	●	●
CH1 [Ch1]	-	●	●	●	●	●	●	●
CH2 [Ch2]	-	●	●	●	●	●	●	●
CH3 [Ch3]	-	●	●	●	●	●	●	●
CH4 [Ch4]	-	●	●	●	●	●	●	●
Total 1 [tot_1]	-	●	●	●		●	●	●
Total 2 [tot_2]	-	●	●	●		●	●	●
Peak [PEAK]	-	○				●	○	●
Valley [VALEY]	-	○				●	○	●
Tare [tArE]	-	○	○	○		●	○	●
PID Output 1	50	○	○	○		○		
PID Output 2	51	○	○	○		○		
Smart Result 1	54	○	○	○				○
Smart Result 2	55	○	○	○				○
Smart Result 3	56	○	○	○				○
Smart Result 4	57	○	○	○				○
Smart Result 5	58							○
Smart Result 6	59							○
Smart Result 7	60							○
Analog Output 1	83	○				○	○	○
Analog Output 2	84	○				○	○	○
Timer 1	95	○				○	○	○
Timer 2	96	○				○	○	○
Smart Reset Offset 1	121							●
Smart Reset Offset 2	122							●
Clock - Seconds	213					○		
Clock - Minutes	214					○		
Clock - Hours	215					○		
Clock - Days	216					○		
Clock - Date	217					○		
Clock - Month	218					○		
Clock - Year	219					○		
Setpoint Latch	221							●
Relay De-energize	222							●
Zero Offset - Result	227					○		
Zero Offset - CH1	228					○		
Zero Offset - CH2	229					○		
Zero Offset - CH3	230					○		
Zero Offset - CH4	231					○		

## Resetting and Incrementing Using Setpoints

Setpoints may be used to reset and/or increment registers. In the example shown on the right, 2 liter soft drink bottles are being filled and packed 12 to a case. Using the setpoint reset and increment feature, the number of bottles and the total number of filled cases is easily calculated and displayed. Totalizer 1 counts from 0 to 2, resets, and repeats. CH 2 counts from 0 to 12, resets, and repeats.



## Registers that Should Not be Used


The following registers are contained within the selectable 1 to 244 Register Set, but they should not be selected because they are either reserved for future use, or for use by the operating system only:

15, 38, 47-48, 52-53, 61-64, 123-128, 140-141, 234-244

Any selection of these Registers may cause a malfunction.


## USING SETPOINTS TO INCREMENT AND RESET REGISTERS

# Functional Diagram



## Connector Pinouts

### Rear Panel Pinout Diagram



**WARNING:** AC and DC input signals and power supply voltages can be hazardous. Do Not connect live wires to screw terminal plugs, and do not insert, remove or handle screw terminal plugs with live wires connected.

### Input Signal – Pins 1 to 6


See the *I-Series Input Modules Guide (Z87)* for connection details of all input modules. On most single input signal conditioners, usually Pin 1 is the signal high pin (Hi +) and Pin 3 is the signal low pin (Lo -).

### Function Pins – Pins 8 to 15

**Pin 8 – Program Lock.** By connecting the PROGRAM LOCK pin to the COMMON pin (pin 11 on the main PCB), the PROGRAM LOCK pin allows the meter's programmed parameters to be viewed but not changed.

**Pin 9 – Hold Reading.** By connecting the HOLD READING pin to the COMMON pin (pin 11), the HOLD READING pin allows the

**NOTE:** The meter uses plug-in type screw terminal connectors for most input and output connections and an RJ-6 phone connector for the optional RS-232 or RS-485 serial outputs.



meter's display to be frozen. However, A/D conversions continue and as soon as pin 9 is disconnected from pin 11 the updated reading is instantly displayed.

**Pin 10 – Display Test and Reset.** The DISPLAY TEST and RESET pin provides a test of the meter's display and resets the microprocessor when the DISPLAY TEST and RESET pin is connected to the COMMON pin (pin 11).

**Pin 11 – Common.** To activate the HOLD, TEST and RESET, or LOCKOUT pins from the rear of the meter, the respective pins have to be connected to the COMMON pin.

**Pins 14/15 – AC/DC Power Input.** These are the pins that supply power to the meter. See Power Supply for details of the standard and optional low voltage power supply.

**Chassis Ground Tab.** Only on versions with metal sheath casing.


# Carrier Board Output Pins

## Analog Outputs

- Pin 16 – Positive (+) analog output 1.
- Pin 17 – Negative (-) analog output 1 and 2.
- Pin 18 – Positive (+) analog output 2.

## Serial Outputs RS-232 or RS-485


Pin No.	RS-232	RS-485
19	Reserved for future use	Reserved for future use
20	RXD. Received Serial	B (Low)
21	TXD. Transmitted Serial	A (High)
22	+5 VDC to power external converters	+5 VDC to power external converters
23	Isolated Ground	Isolated Ground
24	Reserved for future use	Reserved for future use



**Ethernet** – The Ethernet carrier board has the same analog output pins, with 10/100Base-T Ethernet (RJ-45 Socket).


**DeviceNet** – The DeviceNet carrier board has the same analog pinouts, but with a 3.5mm Pitch Socket. The serial output pins are replaced with DeviceNet pins, as follows:

- Pin 19 - Positive (+) 24V.
- Pin 20 - Can + (positive).
- Pin 21 - N/C.
- Pin 22 - Can - (negative).
- Pin 23 - Negative (-) 24V.




## Relay and Logic I/O Modules


**Opto Isolated I/O Module for External Breakout Box with 6 Outputs & 6 Inputs, or 16 Outputs & 6 Inputs**




**Relay Modules with up to two 5A Form A Relays, and up to two 10A Form C Relays**




**Relay Modules with up to 4 Independent 400V (210mA DC only) or (140mA AC/DC) SSRs**




**Relay Modules with five or six 5A Form A Relays**




**Open Collector / TTL / 5V Output**



**Relay Modules with up to four 5A Form A Relays**



**Flash Card Memory Module**




## Modular Construction

The Tiger 320 Series of 32-bit Programmable Meter Controllers incorporates, in one instrument, all the different functions required by today's automation and process control applications. This is made possible by modular construction, around standard case sizes, built to American, European, and Japanese standards.


The range comes with a wide variety of display options, including 5 or 6-digit numeric or alphanumeric displays, 6-digit LCD displays, and 51 or 101-segment red, green, or tri-color straight and circular bargraphs.

All meters are housed in one of three DIN case sizes, or the popular 4" ANSI case, and provide the ideal solution for your measurement and process control applications.


Modular construction ensures you don't have to pay for unnecessary hardware. Simply order the input and output options to suit your application.



**Tiger 320 Series Modular Construction**




**Input Signal Conditioner**



**Main PCB\***

\*Shown with optional Input Signal Conditioning Module (Ordered Separately)




**Standard Output Carrier Board\***

\*Shown with optional Analog Output Module, optional Relay Output Module and a Serial Output Module (RS-232, RS-485 or No Serial Output)

**Ethernet Output Carrier Board\*\***


\*\*Is similar to the Standard Output Module Carrier Board, except that the RJ-6 socket is replaced with a 10/100Base-T RJ-45 Socket




The optional DeviceNet output carrier board supports all analog output modules and relay and logic I/O modules. The 5 pin DeviceNet output and the 3 pin analog output use 3.5mm pitch screw terminal plugs.



**Optional DeviceNet Carrier Board**



**Processor Board**




**Display Board**

Set Point Lock  
Program Lock

Battery for Real-time Clock Option


**Analog Output Module PCB**



Available in Single (0-4-20mA or 0-10V) or Dual (0-10V & 0-10V)

**Standard Serial Output Modules RS-232 or RS-485**

*Note:*  
Externally mounted Ethernet compatible communication output modules are available that connect directly to the standard (RS-232 / RS-485) serial module outputs.




**RS-485 Output Module PCB**



**RS-232 Output Module PCB**

**Opto Isolated I/O Modules Connect to External DIN Rail Mounting Breakout Box**



3M IDC Cable

10 Digital Outputs Add-on Board

DIN Rail Mounting Breakout Box with Screw Terminal Blocks

Standard 6 Digital Inputs/6 Digital Outputs

DIN Rail Relay Module

2  
1  
26  
25



# I-SERIES INPUT SIGNAL CONDITIONING MODULES

Over 120 plug-in signal conditioning modules are available to suit almost any input signal, control, or data output. Modules can be easily inserted through the rear of the meter without disassembly of the case or removal from the panel. Many modules are exclusively designed for the Tiger 320 Series, and some can also be used with the Leopard and Lynx Family panel meters and bargraphs.

Function	Module Page	Function	Module Page	Function	Module Page
<b>AC</b>					
• AC Amps. Scaled RMS	IA04	50	• Process Loop, 4 to 20mA w/24V DC Exc. and AutoCal	IP06	52
• AC Amps. Scaled RMS	IA05	50	• Process Loop, 4 to 20mA with 24V DC Exc.	IP02	52
• AC Amps. True RMS	IA09	50	• Quad 4 to 20mA	IOP1	52
• AC Amps. True RMS	IA11	50	• Smart Dual Input, Load Cell and Process (4-20mA)	ISS9	53
• AC Millamps. Scaled RMS	IA03	50	• Triple 4 to 20mA	ITP1	54
• AC Millamps. True RMS	IA08	50	• Triple - T/C, 4 to 20mA and 4 to 20mA	ITR8	54
• AC Millivolts. Scaled RMS	IA10	50	• Triple - T/C, 4 to 20mA and Counter	ITTF	54
• AC Millivolts. True RMS	IA12	50	• Triple - T/C, 4 to 20mA and DC mV	ITTA	54
• AC Volts. Scaled RMS	IA01	50	• Triple - T/C, 4 to 20mA and DC Volts	ITTB	54
• AC Volts. Scaled RMS	IA02	50	• Triple - T/C, T/C and 4 to 20mA	ITTA	54
• AC Volts. True RMS	IA06	50	<b>FREQUENCY / RPM</b>		
• AC Volts. True RMS	IA07	50	• Dual - Strain Gage and Frequency	IDS3	51
<b>COUNTER</b>					
• Dual - UP/DOWN Counter	IDC1	51	• Dual Frequency	IDF2	51
• Quadrature Counter	IC02	50	• Line Frequency	IF06	51
• Quadrature Counter w/dual SSRs	IC03	50	• Triple RTD / RTD / Frequency	ITTE	54
• Smart Triple Input, Pressure Direct & Dual Counter	ISP1	53	• Triple - T/C, Volts and Frequency	ITTG	54
• Triple - T/C, 4 to 20mA and Counter	ITTF	54	• Universal Freq / RPM / Up Down Counter	IF10	51
• Universal Freq / RPM / Up Down Counter	IF10	51	<b>LVDT</b>		
<b>DC</b>					
• DC Amps	ID04	50	• Smart Dual LVDT (50 Hz)	ISL1*	53
• DC Amps	ID09	51	• Smart Dual LVDT (60 Hz)	ISL2**	53
• DC Millamps	ID03	50	<b>OXIDATION REDUCTION POTENTIAL</b>		
• DC Millamps with Offset and 24V Exc.	ID07	50	• Oxidation Reduction Potential (ORP)	IOR1	52
• DC Millivolts	ID02	50	<b>pH</b>		
• DC Volts	ID01	50	• pH	IHO1	52
• DC Volts with External Decimal Select	ID06	50	• pH with Automatic Temperature Compensation	IHO2	52
• DC Volts with External LIN Table Select	ID08	50	<b>POTENTIOMETER</b>		
• DC Volts with Offset and 24V Exc.	ID05	50	• Linear Potentiometer 1KΩ min	IR03	53
• DC-Watts, 10V/50mV DC	IW03	54	• Smart Dual 3-wire Potentiometer (50 Hz)	ISR3*	53
• Dual - 3-wire RTD and DC V	IDT3	51	• Smart Dual 3-wire Potentiometer (60 Hz)	ISR4**	53
• Dual DC Millamps	IDD3	51	• Smart Quad Potentiometer/Resistance	ISSA	53
• Dual DC Millivolts	IDD2	51	• Smart Single 3-wire Potentiometer (50 Hz)	ISR1*	53
• Dual - DC mV and 4 to 20mA	IDD6	51	• Smart Single 3-wire Potentiometer (60 Hz)	ISR2**	53
• Dual - DC V and 4 to 20mA	IDD5	51	<b>PRESSURE</b>		
• Dual - DC V and DC mV	IDD4	51	• Direct Pressure with 2 Digital Inputs	IGYX	52
• Dual DC Volts	IDD1	51	• Dual Direct Pressure (Absolute or Differential/Gage)	IGYY	52
• Dual - Thermocouple and DC mV	IDT5	51	• Dual Pressure Input	IDS2	51
• Dual - Thermocouple and DC V	IDT4	51	• Dual Smart Pressure/Load Cell, 16 bit	ISS5*	52
• Process Input with Offset and 24V Exc (1-5VDC)	IP03	52	• Dual Smart Pressure/Load Cell, 16 bit	ISS6**	52
• Process + 3 Digital Inputs	IP10	52	• Pressure/Load Cell Ext Exc. High Impedance	IS07	53
• Quad DC mV	IDQ2	52	• Pressure/Load Cell Ext Exc., 4/6-wire	IS04	53
• Quad DC Volts	IDQ1	52	• Pressure/Load Cell Ext Exc., 20/20mV/V, 4-wire	IS06	53
• Smart DC Volts, 16 bit, 1 to 800 Hz update rates	ISD1*	53	• Pressure/Load Cell with AutoCal, 4-wire	IS03	53
• Smart DC Volts, 16 bit, 1 to 960 Hz update rates	ISD2**	53	• Pressure/Load Cell, 4/6-wire	IS02	53
• Smart DC Volts, 16 bit, 1 to 800 Hz w/dual SSRs	ISD3*	53	• Pressure/Load Cell, 20/2mV/V, 5/10V Exc 4-wire	IS05	53
• Smart DC Volts, 16 bit, 1 to 960 Hz w/dual SSRs	ISD4**	53	• Smart Pressure/Load Cell, Standard Res 16 bit	ISS1*	53
• Smart DC Volts, High Res & Acc, 24 bit 1-400Hz	ISD5*	53	• Smart Pressure/Load Cell, Standard Res 16 bit	ISS2**	53
• Smart DC Volts, High Res & Acc, 24 bit 1-480Hz	ISD6**	53	• Smart Pressure/Load Cell, High Res & Acc 24 bit	ISS3*	53
• Smart DC V, High Res & Acc, 1-400Hz w/dual SSRs	ISD7*	53	• Smart Pressure/Load Cell, High Res & Acc 24 bit	ISS4**	53
• Smart DC V, High Res & Acc, 1-480Hz w/dual SSRs	ISD8**	53	• Smart Quad Pressure/Load Cell (50 Hz)	ISS7*	53
• Smart Dual Input DC Volts, 16 bit, 1-20Hz update	ISDA*	53	• Smart Quad Pressure/Load Cell (60 Hz)	ISS8**	53
• Smart Dual Input DC Volts, 16 bit, 1-20Hz update	ISDB**	53	• Smart Triple Input, Pressure Direct & Dual Counter	ISP1	53
• Triple DC mV, 50mV DC	ITD2	54	• Universal Direct Pressure	IGYZ	52
• Triple DC Volts, 2V DC	ITD1	54	<b>PROCESS INPUT</b>		
• Triple - T/C, DC mV and DC mV	ITTF	54	• Process Input with Offset and 24V Exc (1-5VDC)	IP03	52
• Triple - T/C, DC Volts and DC mV	ITTR	54	<b>PROCESS LOOP</b>		
• Triple - T/C, DC Volts and DC Volts	ITTT	54	• Dual Process Loop	IDP1	51
• Triple - T/C, T/C and DC mV	ITTS	54	• Process Loop, 4 to 20mA	IP01	52
• Triple - T/C, T/C and DC V	ITTV	54	• Process Loop, 4 to 20mA (0-100.00) w/ Ext. Lin Table	IP09	52
• Universal Process Input	IP07	52	• Process Loop, 4 to 20mA w/24V DC Exc. and AutoCal	IP06	52
• Universal Process Input with AutoCal	IP08	52	• Process Loop, 4 to 20mA with 24V DC Exc.	IP02	52
<b>DUAL INPUTS</b>					
• Dual - 3-wire RTD and DC V	IDT3	51	<b>QUAD INPUTS</b>		
• Dual - 3-Wire RTD and 4 to 20mA	IDP2	50	• Quad 4 to 20mA	IOP1	52
• Dual DC Millamps	IDD3	51	• Quad DC mV	IDQ2	52
• Dual DC Millivolts	IDD2	51	• Quad DC Volts	IDQ1	52
• Dual - DC mV and 4 to 20mA	IDD6	51	• Quad RTD Platinum 2 wire connection	ITQ2	52
• Dual - DC V and 4 to 20mA	IDD5	51	• Quad RTD Platinum 4 wire connection	ITQ4	52
• Dual - DC V and DC mV	IDD4	51	• Quad - Thermocouple / DC V / DC V / Frequency	ITQ5	52
• Dual DC Volts	IDD1	51	• Smart Quad Potentiometer/Resistance	ISSA	53
• Dual Direct Pressure (Absolute or Differential/Gage)	IGYX	52	• Smart Quad Pressure/Load Cell (50 Hz)	ISS7*	53
• Dual Frequency	IDF2	51	• Smart Quad Pressure/Load Cell (60 Hz)	ISS8**	53
• Dual Pressure Input	IDS2	51	• Smart Quad Thermocouple (50 Hz)	IST3*	54
• Dual Process Loop	IDP1	51	• Smart Quad Thermocouple (60 Hz)	IST4**	54
• Dual Resistance Input	IDR1	51	<b>RESISTANCE</b>		
• Dual RTD Input	IDT2	51	• Dual Resistance Input	IDR1	51
• Dual Smart Pressure/Load Cell, 16 bit	ISS5*	52	• Resistance, 2/3/4-Wire	IR01	52
• Dual Smart Pressure/Load Cell, 16 bit	ISS6**	52	• Smart Quad Potentiometer/Resistance	ISSA	53
• Dual Strain Gage Input	IDS1	51	<b>RTD</b>		
• Dual - Strain Gage and Frequency	IDS3	51	• Dual - 3-wire RTD and DC V	IDT3	51
• Dual Thermocouple	IDT1	51	• Dual - 3-Wire RTD and 4 to 20mA	IDP2	50
• Dual - Thermocouple and 4 to 20mA	IDP3	51	• Dual RTD Input	IDT2	51
• Dual - Thermocouple and DC mV	IDT5	51	• Quad RTD Platinum 2 wire connection	ITQ2	52
• Dual - Thermocouple and DC V	IDT4	51	• Quad RTD Platinum 4 wire connection	ITQ4	52
• Dual - Thermocouple and Load Cell	IDT6	51	• RTD, 100Ω Pt. 2/3/4-wire	ITQ2	54
• Dual UP/DOWN Counter	IDC1	51	• RTD, 100Ω Pt. 2/3/4-wire (-200 to 800°C)	ITQ3	54
• Smart Dual 3-wire Potentiometer	ISR3	53	• RTD, 100Ω Pt. 2/3/4-wire (-200 to 1470°F)	ITQ4	54
• Smart Dual Input, Load Cell and Process (4-20mA)	ISS9	53	• RTD, 100Ω Pt. 2/3/4-wire (-199.9 to 199.9°C)	ITQ5	54
• Smart Dual Input, Load Cell and RTD	ISSB	54	• RTD, 100Ω Pt. 2/3/4-wire (-199.9 to 199.9°F)	IT14	54
• Smart Dual Input DC Volts, 16 bit, 1-20Hz update	ISDA*	53	• RTD, 10Ω Copper 2/3/4-wire	IT13	54
• Smart Dual Input DC Volts, 16 bit, 1-20Hz update	ISDB**	53	• RTD, 120Ω Nickel 2/3/4-wire	IT12	54
• Smart Dual LVDT (50 Hz)	ISL1*	53	• Smart Dual Input, Load Cell and RTD	ISSB	54
• Smart Dual LVDT (60 Hz)	ISL2**	53	• Smart Dual RTD (50 Hz)	IST5*	54
• Smart Dual Photo Diode Input	ISSE	53	• Smart Dual RTD (60 Hz)	IST6**	54
• Smart Dual RTD (50 Hz)	IST5*	54	• Smart 6 Input - 3 RTD, 2 Process, 1 Digital Input	IST1*	54
• Smart Dual RTD (60 Hz)	IST6**	54	• Smart 6 Input - 3 RTD, 2 Process, 1 Digital Input	IST2**	54
<b>4 TO 20mA</b>					
• Dual - 3-Wire RTD and 4 to 20mA	IDP2	50	• Triple RTD Platinum 100Ω RTD 4-wire connection	ITTC	54
• Dual - DC mV and 4 to 20mA	IDD6	51	• Triple RTD Platinum 100Ω RTD 2-wire connection	ITT2	54
• Dual - DC V and 4 to 20mA	IDD5	51	• Triple - RTD / RTD / Frequency	ITTE	54
• Dual Process Loop	IDP1	51	• Triple - T/C, 4 to 20mA and 4 to 20mA	ITR8	54
• Dual - Thermocouple and 4 to 20mA	IDP3	51	• Triple - T/C, 4 to 20mA and Counter	ITTF	54
• Process Loop, 4 to 20mA	IP01	52	• Triple - T/C, 4 to 20mA and DC mV	ITTA	54
• Process Loop, 4 to 20mA (0-100.00) w/ Ext. Lin Table	IP09	52	• Triple - T/C, 4 to 20mA and DC Volts	ITTB	54
<b>SMART MODULES</b>					
• Dual Smart Pressure/Load Cell, 16 bit	ISS5*	52	• Triple - T/C, DC mV and DC mV	ITTF	54
• Dual Smart Pressure/Load Cell, 16 bit	ISS6**	52	• Triple - T/C, DC Volts and DC mV	ITTR	54
• Smart DC Volts, 16 bit, 1 to 800 Hz update rates	ISD1*	53	• Triple - T/C, DC Volts and DC Volts	ITTT	54
• Smart DC Volts, 16 bit, 1 to 960 Hz update rates	ISD2**	53	• Triple - T/C, T/C and 4 to 20mA	ITTA	54
• Smart DC Volts, 16 bit, 1 to 800 Hz w/dual SSRs	ISD3*	53	• Triple - T/C, T/C and DC mV	ITTS	54
• Smart DC Volts, 16 bit, 1 to 960 Hz w/dual SSRs	ISD4**	53	• Triple - T/C, T/C and DC V	ITTV	54
• Smart DC Volts, High Res & Acc, 24 bit 1-400Hz	ISD5*	53	• Triple - T/C, Volts and Frequency	ITTG	54
• Smart DC Volts, High Res & Acc, 24 bit 1-480Hz	ISD6**	53	• Triple Thermocouple	ITT1	54
• Smart DC V, High Res & Acc, 1-400Hz w/dual SSRs	ISD7*	53	<b>TRIPLE INPUTS</b>		
• Smart DC V, High Res & Acc, 1-480Hz w/dual SSRs	ISD8**	53	• Smart Triple Input, Load Cell and Two Digital Inputs	ISSC*	53
• Smart Dual Input DC Volts, 16 bit, 1-20Hz update	ISDA*	53	• Smart Triple Input, Load Cell and Two Digital Inputs	ISSD**	53
• Smart Dual Input DC Volts, 16 bit, 1-20Hz update	ISDB**	53	• Smart Triple Input, Load Cell and Two Digital Inputs	ISSC	54
• Triple DC mV, 50mV DC	ITD2	54	• Smart Triple Input, Pressure Direct & Dual Counter	ISP1	53
• Triple DC Volts, 2V DC	ITD1	54	• Triple 4 to 20mA	ITP1	54
• Triple - T/C, DC mV and DC mV	ITTF	54	• Triple - DC mV, 2V DC	ITD2	54
• Triple - T/C, DC Volts and DC mV	ITTR	54	• Triple - DC Volts, 2V DC	ITD1	54
• Triple - T/C, DC Volts and DC Volts	ITTT	54	• Triple RTD Platinum 100Ω RTD 4-wire connection	ITTC	54
• Triple - T/C, T/C and DC mV	ITTS	54	• Triple RTD Platinum 100Ω RTD 2-wire connection	ITT2	54
• Triple - T/C, T/C and DC V	ITTV	54	• Triple - RTD / RTD / Frequency	ITTE	54
• Universal Process Input	IP07	52	• Triple - T/C, 4 to 20mA and 4 to 20mA	ITR8	54
• Universal Process Input with AutoCal	IP08	52	• Triple - T/C, 4 to 20mA and Counter	ITTF	54
<b>STRAIN GAGE</b>					
• Dual - Strain Gage and Frequency	IDS3	51	• Triple - T/C, 4 to 20mA and DC mV	ITTA	54
• Dual Strain Gage Input	IDS1	51	• Triple - T/C, 4 to 20mA and DC Volts	ITTB	54
• Strain Gage	IS01	53	• Triple - T/C, DC mV and DC mV	ITTF	54
<b>THERMOCOUPLE</b>					
• Dual Thermocouple	IDT1	51	• Triple - T/C, DC Volts and DC mV	ITTR	54
• Dual - Thermocouple and 4 to 20mA	IDP3	51	• Triple - T/C, DC Volts and DC Volts	ITTT	54
• Dual - Thermocouple and DC mV	IDT5	51	• Triple - T/C, T/C and 4 to 20mA	ITTA	54
• Dual - Thermocouple and DC V	IDT4	51	• Triple - T/C, T/C and DC mV	ITTS	54
• Dual - Thermocouple and Load Cell	IDT6	51	• Triple - T/C, T/C and DC V	ITTV	54
• Quad - Thermocouple / DC V / DC V / Frequency	ITQ5	52	• Triple - T/C, Volts and Frequency	ITTG	54
• Smart Quad Thermocouple (50 Hz)	ISS7*	53	• Triple Thermocouple	ITT1	54
• Smart Quad Thermocouple (60 Hz)	ISS8**	53	<b>TRIPLE INPUTS</b>		
• Thermocouple	IT01	54	• Smart Triple Input, Load Cell and Two Digital Inputs	ISSC*	53
• Triple - T/C, 4 to 20mA and 4 to 20mA	ITR8	54	• Smart Triple Input, Load Cell and Two Digital Inputs	ISSD**	53
• Triple - T/C, 4 to 20mA and Counter	ITTF	54	• Smart Triple Input, Load Cell and Two Digital Inputs	ISSC	54
• Triple - T/C, 4 to 20mA and DC mV	ITTA	54	• Smart Triple Input, Pressure Direct & Dual Counter	ISP1	53
• Triple - T/C, 4 to 20mA and DC Volts	ITTB	54	• Triple 4 to 20mA	ITP1	54
• Triple - T/C, DC mV and DC mV	ITTF	54	• Triple - DC mV, 2V DC	ITD2	54
• Triple - T/C, DC Volts and DC mV	ITTR	54	• Triple - DC Volts, 2V DC	ITD1	54
• Triple - T/C, DC Volts and DC Volts	ITTT	54	• Triple RTD Platinum 100Ω RTD 4-wire connection	ITTC	54
• Triple - T/C, T/C and 4 to 20mA	ITTA	54	• Triple RTD Platinum 100Ω RTD 2-wire connection	ITT2	54
• Triple - T/C, T/C and DC mV	ITTS	54	• Triple - RTD / RTD / Frequency	ITTE	54
• Triple - T/C, T/C and DC V	ITTV	54	• Triple - T/C, 4 to 20mA and 4 to 20mA	ITR8	54
• Triple - T/C, Volts and Frequency	ITTG	54	• Triple - T/C, 4 to 20mA and Counter	ITTF	54
• Triple Thermocouple	ITT1	54	• Triple - T/C, 4 to 20mA and DC mV	ITTA	54
<b>*Optimized for 50 Hz rejection.</b>					
<b>**Optimized for 60 Hz rejection.</b>					

# I-Series Input Signal Conditioning Modules continued

Many additional input modules are available and others are constantly being developed. Check with your local distributor or see Texmate's web site at: [www.texmate.com](http://www.texmate.com) for updated information. Pre calibrated **I-Series Input Modules**, that have span or zero potentiometers, **can be interchanged between any I-Series compatible meter**, without recalibration, because all of the analog scaling and reference circuitry is self-contained within the module. Where appropriate, all the standard ranges are designed to be header selectable by the user, and our unique **SPAN ADJUST** Header facilitates **scaling to almost any required engineering unit**. See Input Module Component Glossary for more information.

Unless otherwise specified, we will ship all modules pre calibrated with factory preselected ranges and/or scaling as shown in **BOLD** type. Other pre calibrated standard ranges or custom ranges may be ordered. Factory installed custom scaling and other custom options are also available.


Symbols Indicate Module Compatibility Within Meter Families		
TIGER Family	LEOPARD Family	LYNX Family
TIGER Family	LEOPARD Family	LYNX Family
TIGER Family	LEOPARD Family	LYNX Family
<b>ALL MODELS</b>	<b>SOME MODELS</b>	<b>MODEL SPECIFIC</b>

\* TIGER IT03  
\* indicates another module is available, similar in function, which may be more suited for use with that family.


\*\* LYNX FX-B101Q  
\*\* Modules which are compatible are listed below the Model Specific Symbol.

Indicates a SMART MODULE. Smart Modules incorporate their own microprocessor and A/D converter. They communicate digitally with the Tiger 320 Operating System. Some also have their own SSR outputs.


IA01: AC Volts Scaled RMS, 200/600V AC




IA08: AC Milliamps True RMS, 2/20/200mA AC




ID02: DC Millivolts, 20/50/100/200mV DC w/24V DC Exc




IA02: AC Volts Scaled RMS, 200mV/2V/20V AC




IA09: AC Amps True RMS, 1 Amp AC  
IA11: AC Amps True RMS, 5 Amp AC




ID03: DC Milliamps, 2/20/200mA DC w/24V DC Exc




IA03: AC Milliamps Scaled RMS, 2/20/200mA AC




IA10: AC Millivolts, Scaled RMS, 100mV AC




ID04: DC Amps, 5A DC  
ID09: DC Amps, 1A DC




IA04: AC Amps Scaled RMS, 1 Amp AC  
IA05: AC Amps Scaled RMS, 5 Amp AC




IA12: AC Millivolt RMS Sigma Delta




ID05: DC Volts 2/20/200/Custom V DC with Offset and 24V Exc.




IA06: AC Volts True RMS, 300/600V AC




IC02: Quadrature Counter  
IC03: Quadrature Counter w/dual SSRs




ID06: DC Volts 2/20/200/Custom V DC with External Decimal Select




IA07: AC Volts True RMS, 200mV/2V/20V AC



ID01: DC Volts, 2/20/200V/Custom w/24V DC Exc




ID07: DC Milliamps, 2/20/200mA DC with Offset and 24V Exc




# I-Series Input Signal Conditioning Modules continued


**ID08: DC Volts, 2/20/200/Custom V DC with External LIN Table Select**




**IDP1: Dual Process Loop, 4-20mA**




**IDT2: Dual RTD Input, 2/3-wire, 100 Pt**




**IDC1: Dual UP/DOWN Counter**




**IDP2: Dual Input, 3-wire RTD and 4-20mA**




**IDT3: Dual Input, 3-wire RTD and DCV**




**IDD1: Dual DC Volts, 2V DC  
IDD2: Dual DC Millivolts, 50mV DC**




**IDP3: Dual Input- Thermocouple (J/K/R/S/T/B/N) and 4 to 20mA**




**IDT4: Dual Input- Thermocouple (J/K/R/S/T/B/N) and 2VDC Input  
IDT5: Dual Input- Thermocouple (J/K/R/S/T/B/N) and 50mV Input**




**IDD3: Dual DC Milliamps, 2mA DC**




**IDR1: Dual Resistance Input, 0.2/2/20K**




**IDT6: Dual Input - Thermocouple and Load Cell**




**IDD4: Dual Input, DCV and DCmV 2V/50mV DC**




**IDS1: Dual Strain Gage Input, 4 wire 2mV/V, 20mV/V**




**IF06: Line Frequency**




**IDD5: Dual Input, DCV and 4 to 20mA 2V/4 to 20mA DC**




**IDS2: Dual Pressure Input, 4 wire 2mV/V, 20mV/V**




**IF10: Univ. Freq. / RPM / UP DOWN Counter**




**IDD6: Dual Input, DC mV and 4 to 20mA 50mV/4 to 20mA DC**




**IDS3: Dual Input, Strain Gage and Frequency**




**TTL Input Connected to IF10**




**IDF2: Dual Frequency**



**IDT1: Dual Thermocouple (J/K/R/S/T/B/N)**




**Tach Generator Connected to IF10**




# I-Series Input Signal Conditioning Modules continued


## NAMUR Sensor Connected to IF10




## PNP Open Collector Proximity Switch Connected to IF10




## Switch or Dry Contact Connected to IF10




## Magnetic Pickup Connected to IF10




## IGYX: Direct Pressure (Absolute or Differential/Gage) with 2 Digital Inputs. See below for ordering code options



## IGYY: Dual Direct Pressure (Absolute or Differential/Gage) see below for ordering code options



## IGYZ: Universal Direct Pressure (Absolute or Differential/Gage) See below for ordering code options




### Ordering Code Options for Direct Pressure (IGYX, IGYY & IGYZ)

Sensor Range	CH1 Order Code	CH2 Order Code
1 psi Absolute	A	A
1 psi Differential	B	B
5 psi Absolute	C	C
5 psi Differential	D	D
15 psi Absolute	E	E
15 psi Differential	F	F
30 psi Absolute	G	G
30 psi Differential	H	H
100 psi Absolute	I	I
100 psi Differential	K	K


For Single Channel IGYX with two digital inputs, the last digit of order code is always X.

For Universal Direct Pressure IGYZ, the last digit of order code is always Z.


## IHO1: pH IHO2: pH with Automatic Temperature Compensation




## IOR1: ORP (Oxidation Reduction Potential)




## IP01: Process Loop, 4-20mA IP02: Process Loop, 4-20mA with 24VDC EXC




## IP03: Process Input, 1-5V DC with Offset, 24V Exc




## IP06: Process Loop, 4-20mA w/24VDC Exc and Autocal




## IP07: Universal Process Input 2V/5V/10V/20V/200V/2mA/20mA/Custom




## IP08: Universal Process Input with Autocal 2V/5V/10V/20V/200V/2mA/20mA/Custom




## IP09: 4-20mA with External LIN Table Select




## IP10: Process + 3 Digital Inputs




## IPT1: Prototype Board for Custom Design




## IQD1: Quad DC Volts, 2V DC IQD2: Quad DC mV, 50mV DC




## IQP1: Quad 4 to 20mA




## IQT2: Quad RTD Platinum 100 RTD 2 Wire Connection




## IQT4: Quad RTD Platinum 100 RTD 4 Wire Connection



## IQT5: Quad RTD / V / V / FREQ




## IR01: Resistance, 2/3/4-Wire, 200 / 2K / 20K




# I-Series Input Signal Conditioning Modules continued


IRO3: Linear Potentiometer 1KΩ min




ISO1: Strain Gage 5/10VDC Exc., 20/2mV/V, 4/6-wire  
ISO2: Pressure/Load Cell 5/10VDC Exc., 20/2mV/V, 4/6-wire




ISO3: Pressure/Load Cell with AutoCal 5/10VDC Exc., 20/2mV/V, 4-wire




ISO4: Pressure/Load Cell Ext Exc., 20/2mV/V, 4/6-wire




ISO5: Pressure/Load Cell 20/2mV/V, 5/10V Exc 4-wire




ISO6: Pressure/Load Cell Ext Exc., 20/2mV/V, 4-wire




ISO7: Pressure/Load Cell Ext Exc. High Impedance, 20/2mV/V, 4/6-wire




ISD1: Smart DC Volts. 16 bit. Optimized for 50 Hz rejection.  
ISD2: Smart DC Volts. 16 bit. Optimized for 60 Hz rejection.  
ISD3: Smart DC Volts. 16 bit. 50 Hz rejection w/dual SSRs.  
ISD4: Smart DC Volts. 16 bit. 60 Hz rejection w/dual SSRs.




ISD5: Smart DC Volts. 24 Bit. 50 Hz rejection.  
ISD6: Smart DC Volts. 24 Bit. 60 Hz rejection.  
ISD7: Smart DC Volts. 24 Bit. 50 Hz w/dual SSRs.  
ISD8: Smart DC Volts. 24 Bit. 60 Hz w/dual SSRs.




ISD9: Smart Voltage and Resistance Input




ISDA: Smart Dual DC Volts. 16 bit. 50 Hz rejection.  
ISDB: Smart Dual DC Volts. 16 bit. 60 Hz rejection.




ISL1: Smart Dual LVDT. 50 Hz  
ISL2: Smart Dual LVDT. 60 Hz




ISM1: Smart Magnetostrictive Input




ISP1: Smart Triple Input, Pressure Direct and Dual Counter (Frequency/Counter)




ISR1: Smart Single 3-Wire Potentiometer. 24 bit. 50 Hz  
ISR2: Smart Single 3-Wire Potentiometer. 24 bit. 60 Hz




ISR3: Smart Dual 3-Wire Potentiometer. 16 bit. 50 Hz  
ISR4: Smart Dual 3-Wire Potentiometer. 16 bit. 60 Hz




ISS1: Smart Pressure/Load Cell. 16 bit (50 Hz rejection)  
ISS2: Smart Pressure/Load Cell. 16 bit (60 Hz rejection)  
ISS3: Smart Pressure/Load Cell. 24 bit (50 Hz rejection)  
ISS4: Smart Pressure/Load Cell. 24 bit (60 Hz rejection)




ISS5: Dual Smart Pressure. 16 bit. Optimized for 50 Hz rejection.  
ISS6: Dual Smart Pressure. 16 bit. Optimized for 60 Hz rejection.




ISS7: Smart Quad Pressure/Load Cell. 16 bit. 50 Hz  
ISS8: Smart Quad Pressure/Load Cell. 16 bit. 60 Hz




ISS9: Smart Dual Input, LC and Process (4-20mA)




ISSA: Smart Quad Potentiometer/Resistance




ISSB: Smart Dual Input, Load Cell and RTD



ISSC: Smart Triple Input, 16 bit, Load Cell and two Digital Inputs (Frequency/Counter) (Optimized for 50 Hz)  
ISSD: Smart Triple Input, 16 bit, Load Cell and two Digital Inputs (Frequency/Counter) (Optimized for 60 Hz)




ISSE: Smart Dual Photo Diode Input




# I-Series Input Signal Conditioning Modules continued


IST1: Smart 6 Inputs- 3 RTDs, 2 Proc. & 1 Dig. Input. 50 Hz  
 IST2: Smart 6 Inputs- 3 RTDs, 2 Proc. & 1 Dig. Input. 60 Hz




IST3: Smart Quad Thermocouple. 50 Hz  
 IST4: Smart Quad Thermocouple. 60 Hz




IST5: Smart Dual RTD with 0.01° Res. 50 Hz  
 IST6: Smart Dual RTD with 0.01° Res. 60 Hz




IT01: Thermocouple (J/K/R/S/T/B/N)




IT02: RTD, 100 Pt. 2.3/4-wire  
 IT12: RTD, 120 Nickel 2/ 3/4-wire  
 IT13: RTD, 10 Copper 2/ 3/4-wire




IT03: RTD, 100 Pt. 2/ 3/4-wire (-200 to 800°C)  
 IT04: RTD, 100 Pt. 2/ 3/4-wire (-200 to 1470°F)  
 IT05: RTD, 100Ω Pt. 2/3/4-wire (-199.9 to 199.9°F)  
 IT14: RTD, 100Ω Pt. 2/3/4-wire (-199.9 to 199.9°C)




ITD1: Triple DC Volts, 2V DC  
 ITD2: Triple DC mV, 50mV DC




ITP1: Triple 4 to 20mA



ITT1: Triple Thermocouple (J/K/R/S/T/B/N)




ITT2: Triple RTD Platinum 100 RTD  
 2 Wire Connection




All three RTDs must be connected for the meter to work.


ITT3: Triple Input- T/C, T/C (J/K/R/S/T/B/N)  
 and 2VDC Input  
 ITT5: Triple Input- T/C, T/C (J/K/R/S/T/B/N)  
 and 50mV DC




ITT4: Triple Input- T/C, T/C (J/K/R/S/T/B/N)  
 and 4 to 20mA




ITT6: Triple Input- T/C (J/K/R/S/T/B/N),  
 50mV DC and 50mV DC  
 ITT7: Triple Input- T/C (J/K/R/S/T/B/N),  
 2VDC and 2VDC




ITT8: Triple Input- T/C (J/K/R/S/T/B/N),  
 4 to 20mA and 4 to 20mA




ITT9: Triple Input- T/C (J/K/R/S/T/B/N),  
 DCV and 50mV DC



ITTA: Triple Input- T/C (J/K/R/S/T/B/N),  
 4 to 20mA and 50mV DC  
 ITTB: Triple Input- T/C (J/K/R/S/T/B/N),  
 4 to 20mA and 2VDC




ITTC: Triple RTD Platinum 100 RTD  
 4 Wire Connection




All three RTDs must be connected for the meter to work.


ITTE: Triple Input- RTD / RTD / FREQ




ITTF: Triple Input - Thermocouple / 4-20mA / Frequency  
 ITTG: Triple Input - Thermocouple / V / Frequency



IWO1: Single Phase Power, 300V/1A  
 IWO2: Single Phase Power, 300V/5A  
 IWO4: Single Phase Power, 700V/1A  
 IWO5: Single Phase Power, 700V/5A




IWO3: DC-Watts, 10V/50mV DC



# INPUT MODULE COMPONENT GLOSSARY

Dual input modules, and those modules exclusively compatible with the Leopard or Tiger Families, do not have zero and span adjustments. These modules are scaled and calibrated using the internal software functions of each individual meter.




### Input and Output Pins

On most modules Pin 1 is the Signal High input and Pin 3 is the Signal Low input. Typically Pin 2 is used for Excitation Voltage output.




### 24 V DC Output for 4-20 mA Header

On some modules this header enables a 24 V DC 25 mA (max) Excitation/Auxiliary output to be connected to Pin 2 that can power most 4-20 mA transmitters.




### INPUT RANGE Headers

Range values are marked on the PCB. Typically two to eight positions are provided, which are selected with either a single or multiple jumper clip. When provided, a custom range position is only functional when the option has been factory installed.



### SPAN Potentiometer (Pot)



If provided, the 15 turn SPAN pot is always on the right side (as viewed from the rear of the meter). Typical adjustment is 20% of the input signal range.



### SPAN ADJUST Header

This unique five-position header expands the adjustment range of the SPAN pot into five equal 20% steps, across 100% of the input Signal Span. Any input Signal Span can then be precisely scaled down to provide any required Display span from full scale to the smallest viewable unit.

SPAN Adjust Header position	1	2	3	4	5
SPAN Pot %	20%	20%	20%	20%	20%
Signal Span %	20%	40%	60%	80%	100%





### SPAN RANGE Header

When this header is provided it works in conjunction with the SPAN ADJUST Header by splitting its adjustment range into a Hi and a Lo range. This has the effect of dividing the adjustment range of the SPAN pot into ten equal 10% steps across 100% of the input Signal Span.





SPAN Adjust Header position	1	2	3	4	5	1	2	3	4	5
SPAN Pot %	10%	10%	10%	10%	10%	10%	10%	10%	10%	10%
Signal Span %	10%	20%	30%	40%	50%	60%	70%	80%	90%	100%




### Function Select Headers

On some modules various functions such as Amps and Volts, 4 wire and 6 wire, or cold junction compensation are selected by header positions that are marked on the PCB.





### Excitation Output Select Headers

When excitation outputs are provided, they are typically 5 V DC max 30 mA, 10 V DC max 30 mA (300Ω or higher resistance) or external supply. They are selected by either a single or multiple jumper clip.





### ZERO Potentiometer (Pot)

If provided, the ZERO pot is always to the left of the SPAN pot (as viewed from the rear of the meter). Typically it enables the input signal to be offset ±5% of the full scale display span.




### ZERO OFFSET RANGE Header

When provided, this three position header increases the ZERO pot's capability to offset the input signal, by ±25% of the full scale display span. For example a Negative offset enables a 1 to 5 V input to display 0 to full scale. The user can select negative offset, positive offset, or no offset (ZERO pot disabled for two step non-interactive span and offset calibration).




### ZERO ADJUST Header

When this header is provided, it works in conjunction with the ZERO OFFSET RANGE Header, and expands the ZERO pot's offset capability into five equal negative steps or five equal positive steps. This enables virtually any degree of input signal offset required to display any desired engineering unit of measure.





# Case Dimensions

## PANEL CUTOUT




## SIDE VIEW





The 96x48mm case is particularly suitable for mounting in mosaic panels or insulative panels up to 2" thick. They can also stack mount, 2 up in existing cutouts for 1/4 DIN (96x96mm) or 4 up in 1/2 DIN (96x192mm).

**Metal Surround Case**  
P/N:(OP-MTL96X48) uses Metal Screw Mount Clips and has a max. panel thickness mounting of 15.5 mm (0.61").

NOTE: The Metal Surround Case is pre-installed at the factory and cannot be removed without damage to the case.




## TOP VIEW






Various bezel colors are available. Black is standard.

**Clear Lockable NEMA 4X Splash Proof Cover**  
P/N:(OP-N4/96x48)



## FRONT VIEW

1/8 DIN 96x48mm



## WARRANTY

Texmate warrants that its products are free from defects in material and workmanship under normal use and service for a period of one year from date of shipment. Texmate's obligations under this warranty are limited to replacement or repair, at its option, at its factory, of any of the products which shall, within the applicable period after shipment, be returned to Texmate's facility, transportation charges pre-paid, and which are, after examination, disclosed to the satisfaction of Texmate to be thus defective. The warranty shall not apply to any equipment which shall have been repaired or altered, except by Texmate, or which shall have been subjected to misuse, negligence, or accident. In no case shall Texmate's liability exceed the original purchase price. The aforementioned provisions do not extend the original warranty period of any product which has been either repaired or replaced by Texmate.

## USER'S RESPONSIBILITY

We are pleased to offer suggestions on the use of our various products either by way of printed matter or through direct contact with our sales/application engineering staff. However, since we have no control over the use of our products once they are shipped, NO WARRANTY WHETHER OF MERCHANTABILITY, FITNESS FOR PURPOSE, OR OTHERWISE is made beyond the repair, replacement, or refund of purchase price at the sole discretion of Texmate. Users shall determine the suitability of the product for the intended application before using, and the users assume all risk and liability whatsoever in connection therewith, regardless of any of our suggestions or statements as to application or construction. In no event shall Texmate's liability, in law or otherwise, be in excess of the purchase price of the product.

Texmate cannot assume responsibility for any circuitry described. No circuit patent or software licenses are implied. Texmate reserves the right to change circuitry, operating software, specifications, and prices without notice at any time.



995 Park Center Drive • Vista, CA 92081-8397

Tel: 1-760-598-9899 • USA 1-800-839-6283 • That's 1-800-TEXMATE

Fax: 1-760-598-9828 • Email: sales@texmate.com • Web: www.texmate.com

Texmate has facilities in Japan, New Zealand, Taiwan, and Thailand. We also have authorized distributors throughout the USA and in 28 other countries.

For product details visit [www.texmate.com](http://www.texmate.com)

Local Distributor Address